




CPL



## CFD Wind Dispersion Study of Heated Exhaust From STAMP Data Centers

June 19<sup>th</sup>, 2026

M/E Reference: 260210.00

## Section 1: Introduction

- Overview of Study

## Section 2: Model Parameters

- Wind Direction & Speed Data
- Model Geometry
- Mechanical Information

## Section 3: Case Study

- Base Case – North Site: Evaluation of Two Data Centers at Northern STAMP Site
- Base Case – South Site: Evaluation of One Data Center at Southern STAMP Site

## Section 4: Analysis & Conclusions

# Introduction

## Overview of Study

Section  
1


- Salas O'Brien Consulting and Engineering Group of New York, Inc. (FKA M/E Engineering) has prepared a Computational Fluid Dynamics (CFD) wind dispersion study on behalf of CPL to assess the expected windborne distribution of heated exhaust air as it is released from a selection of equipment proposed to serve three large data centers across two sites (Project Double Reed) located within the Science & Technology Advanced Manufacturing Park (STAMP) site. The STAMP site is located to the east of the Tonawanda Seneca Nation's Territory and within the town of Alabama, NY
- Data centers require substantial cooling capacity to maintain strict interior conditions for the optimal operation of the computational and supporting equipment and so the generated heat from within the space must be migrated and released to the atmosphere
- This study aims to assess and respond to comments and concerns related to the project design and its potential effect on the nearby environment regarding elevated temperatures nearby to the data centers, due to the airborne dispersion of their heated exhaust, by simulating the expected distribution of temperature around the modeled data centers
  - This study assesses the predicted potential for Project Double Reed to elevate nearby temperatures, if any, and quantify the potential effect on the adjacent Tonawanda Seneca Nation Territory and Town
- Two scenarios are evaluated:
  - Base Case – North Site: Evaluation of heated exhaust released from the two large data centers located at the northern STAMP site under atypical ambient conditions comprising a wind speed of 10 mph and an ambient temperature of 87.2 F
  - Base Case – South Site: Evaluation of heated exhaust released from the single large data center located at the southern STAMP site under atypical ambient conditions comprising a wind speed of 10 mph and an ambient temperature of 87.2 F
- Display of results:
  - Airborne dispersion of heated exhaust air will be displayed as animated volumetric renderings

# Model Parameters

## Wind Direction & Speed Data – July



Windrose Plot for [GVQ] Batavia  
Obs Between: 01 Jul 2018 12:56 AM - 31 Jul 2025 11:56 PM America/New\_York  
↳ constraints: Jul



- A historical wind rose plot is shown for the STAMP site. The data has been generated between 2018 and 2025 as measured from the Genesee County Airport which is located nearby in Batavia, NY
- The different colors shown on the wind rose represent the wind speed ranges for each compass direction. The length of the different color bands indicate the probability of that wind speed at the associated direction
  - The longer the color band, the higher the probability of that wind direction based on this historical data
- Average July Wind Speed: 7.4 mph
- Simulated July Wind Speed: 10 mph
  - A wind speed of 10 mph has been simulated to account for periodic gusting


Data Source: <http://mesonet.agron.iastate.edu>

# Model Parameters

## Wind Direction & Speed Data – July

The bar chart below shows the same information as the preceding July wind rose plot, except that the probability of the wind direction here is independent of wind speed and calm days are not included (low wind velocity, therefore no discernable wind direction). The information below indicates that the most frequent wind directions are generally from the south-west. Prevailing winds from this most frequent direction will effectively “push” heated exhaust plumes away from the Tonawanda Seneca Nation throughout the year and across the remainder of the STAMP site

Percent of July - Wind Blowing From Direction - Independent of Wind Speed




# Model Parameters

## Wind Direction & Speed Data – Yearly



Windrose Plot for [GVQ] Batavia  
Obs Between: 21 Jun 2018 04:56 PM - 29 Apr 2026 02:56 AM America/New\_York



- An additional wind rose is also provided which describes the average wind directions over an entire year, and which reinforces that the most frequent prevailing winds will generally carry the exhaust plume away from the Tonawanda Seneca Nation
- A July condition was modeled as that month contains the highest average ambient air temperatures which aid to represent a reasonable “worst-case” scenario. The modeled 87.2 °F ambient temperature aligns with the overall mechanical sizing condition and exceeds the ASHRAE 99.6% cooling design condition temperature as measured from the Buffalo Niagara International Airport of 86.6 °F
- For a given winter condition, it is expected that the plume buoyancy due to the large temperature difference against the surrounding chilled ambient air will both carry the plume higher into the atmosphere, and would better dilute the overall temperature of the plume


Data Source: <http://mesonet.agron.iastate.edu>

# Model Parameters

## Wind Direction & Speed Data – Yearly

The bar chart below shows the same information as the preceding yearly wind rose plot, except that the probability of the wind direction here is independent of wind speed and calm days are not included (low wind velocity, therefore no discernable wind direction). The information below indicates that the most frequent wind directions continue to generally arrive from the south-west. Prevailing winds from this most frequent direction will effectively “push” heated exhaust plumes away from the Tonawanda Seneca Nation throughout the year

Percent of Year - Wind Blowing From Direction - Independent of Wind Speed




# Model Parameters

## Wind Direction & Speed Data


- A wind speed of 10 mph was modelled to partially account for gusting conditions. The wind direction was dynamically changed in thirty-degree increments from 5°(NNE) to 335°(NNW). Each wind direction was maintained for a dwell time of 70 seconds
- Shown below is a compass that indicates the wind direction and corresponding wind 'blowing from' angle
  - For example; NE, 35°, indicates that the wind is blowing from the northeast which is equal to a compass direction of 35°
- The remaining un-highlighted space on the compass below indicates that the final wind direction is at 335°, such that if the prevailing winds were indexed once more by 30°, the prevailing wind would return back to its initial starting direction – that being 5° (or 365°)

Yellow area indicates wind directions (in thirty-degree increments) used in the study where wind direction was varied




# Model Parameters

## Model Geometry – STAMP Site Plan View



### LEGEND



- STAMP BOUNDARY
- PUBLIC ROADS
- PARKING AREAS
- COMMERCIAL / MIXED USE / RETAIL
- EXISTING STORMWATER MANAGEMENT
- **SWM** PROPOSED STORMWATER MANAGEMENT
- SITE ENTRANCE POINT
- CONSERVATION EASEMENT
- POWER LINES
- - - POWER LINE EASEMENT
- - - ROADWAY EASEMENT
- - - ZONING SETBACK
- - - 100' AG RESIDENTIAL BUFFER
- - - 300' OPEN SPACE BUFFER



South Site Model


# Model Parameters

## Model Geometry – North Site Plan View



# Model Parameters


## Model Geometry – North Site Isometric View



Isometric View of North  
Site CFD Model Domain

# Model Parameters


## Model Geometry – North Site Isometric View (Close)




Isometric View of North  
Site CFD Model Domain

# Model Parameters

## Model Geometry – South Site Plan View




# Model Parameters



## Isometric View of South Site CFD Model Domain

# Model Parameters

## Model Geometry – South Site Isometric View (Close)



Isometric View of South  
Site CFD Model Domain

# Model Parameters

## Model Geometry – Additional Notes

- Since the modeled region is largely composed of farmland and is only minorly forested, as a conservative estimate, no trees or flora of any kind are included in the model
  - It is expected that trees and other plants would either absorb heat away from the plume or induce additional turbulence which would cause enhanced mixing of the plume with the ambient air – thereby reducing its temperature
- The radiant effect of direct sunlight is not explicitly modeled but its major effects are captured by assigning static surface temperatures to walls, roofs, and the terrain surrounding either site
  - The bulk grassy terrain and all walls are held at the ambient temperature of 87.2 °F while the rooftops and area directly adjacent to the facilities comprising the full site area is held at an elevated temperature of 93.2 °F


# Model Parameters

## Mechanical Information – Equipment Set

- The data centers are served by a set of typical mechanical equipment including air cooled chillers, dedicated outside air systems (DOAS), rooftop units (RTUs), condensing units (CUs), and transformers
  - Each of the three data center facilities are served by identical mechanical layouts comprised by the following typical unit counts per building:
    - Chillers: 60 units
    - DOAS: 6 units with two design variations
    - RTUs: 9 units with four design variations
    - CUs: 88 units with two design variations
    - Transformers: 84 units
- Although the site includes emergency propane generators, these units are for life-safety emergencies only and so only one unit is provided to serve each data center
  - These units are not included in the model since they are intended only for life safety emergencies and will therefore not operate during typical conditions, except for regular monthly testing and maintenance, such that their inclusion within the model is not expected to result in any significant deviation from the expected typical plume dispersion as reported
- The explicitly modeled mechanical parameters of each unit are described in a following slide titled “Exhaust Temperature Calculation”
- To reasonably simplify the computational model, the typical equipment geometry is simplified to focus only on their most important features
  - A selection of images describing the simplified geometry can be found on the following slides, along with an example plan view of a typical data center rooftop


# Model Parameters

## Mechanical Information – Equipment Set 1




The undercarriage geometry of the chiller is not explicitly modeled but the air intake surface along the bottom side is maintained

CU 110kW






CU 50kW



Note: GREEN surfaces represent the modeled exhaust air locations while RED surfaces represent modeled intake air locations

# Model Parameters

## Mechanical Information – Equipment Set 2




Note: GREEN surfaces represent the modeled exhaust air locations while RED surfaces represent modeled intake air locations


# Model Parameters

## Mechanical Information – Equipment Set 3


DOAS



RTU-3A




Transformer



Note: GREEN surfaces represent the modeled exhaust air locations while RED surfaces represent modeled intake air locations

# Model Parameters

## Mechanical Information – Typical Equipment Rooftop Layout Plan



Note: GREEN surfaces represent the modeled exhaust air locations

# Model Parameters

## Mechanical Information – Exhaust Temperature Calculation

- To reasonably simplify the computational model, the expected exhaust temperatures of each equipment unit was precalculated and used as a model input based on the expected intake temperature, volume flow rate of air, and the heat release
- The calculation for each equipment follows the consistent typical heat transfer formulation below:
  - $T_{exh} = \frac{Q}{C_p \cdot \dot{m}} + T_{in}$  where  $T_{exh}$  is the calculated exhaust temperature (K),  $T_{in}$  is the intake air temperature (K) and is assumed to be equal to the ambient temperature of 87.2 °F,  $Q$  is the heat released to the air stream (W),  $C_p$  is the specific heat capacity of air at the at the intake temperature and is assumed to have a value of 1006 J/kg-K, and  $\dot{m}$  is the mass flow rate (kg/s) of the intake air based on the prescribed volume flow rate (m<sup>3</sup>/s) and multiplied by the air density at the assumed intake temperature with a value of 1.16 kg/m<sup>3</sup>
- The intake air volumes of each typical equipment is also modeled so to better capture the expected airflow dynamics above the data centers and mirror the exhaust volumes
- Each transformer emits a steady heat release of 98,621 BTU/hr (28,903 W)
- The input heat release values, air volume flow rates, and resulting exhaust temperatures for each typical equipment is presented below:

| Unit         | Heat Release (BTU/hr) | Volume Flow Rate (ft <sup>3</sup> /min) | Calculated Exhaust Temperature (F) |
|--------------|-----------------------|-----------------------------------------|------------------------------------|
| DOAS 1/2     | 307,648               | 16,600                                  | 104.9                              |
| DOAS 3-6     | 334,324               | 16,600                                  | 106.5                              |
| RTU-1A       | 295,080               | 16,600                                  | 104.2                              |
| RTU-2A       | 297,710               | 16,600                                  | 104.3                              |
| RTU-3A       | 420,109               | 16,600                                  | 111.4                              |
| RTU-01/05/06 | 187,233               | 12,000                                  | 102.1                              |
| RTU-02/03/04 | 194,874               | 12,000                                  | 102.7                              |
| Chiller      | 8,100,000             | 458,853                                 | 104.1                              |
| CU 110 kW    | 423,400               | 28,632                                  | 101.3                              |
| CU 50 kW     | 255,020               | 14,100                                  | 104.5                              |

### **Base Case – North Site: Evaluation of heated exhaust released from two data centers under atypical ambient conditions**


Objective: Determine the expected transient behavior of heated exhaust air from a series of typical equipment serving two large data centers located at the northern site within the STAMP site

The migration of the exhaust plumes are affected by atypical ambient conditions comprising an ambient temperature of 87.2 °F with a wind speed of 10 mph from varying directions in a full 360° arc centered around the facilities


# Base Case – North Site

## Plan View

Section  
3



*Solution Time 275 (s)  
Temperature (F): 87.2  
Windspeed (mph): 10.0  
Prevailing Wind Direction (deg): 95*




*Note: The extended plumes seen in the first few animation frames are due to a pre-calculated approximate solution used to seed the model initial conditions*

# Base Case – North Site

## Isometric View

Section  
3



Note: The extended plumes seen in the first few animation frames are due to a pre-calculated approximate solution used to seed the model initial conditions

### **Base Case – South Site: Evaluation of heated exhaust released from a data center under atypical ambient conditions**


Objective: Determine the expected transient behavior of heated exhaust air from a series of typical equipment serving a large data center located at the southern site within the STAMP site

The migration of the exhaust plumes are affected by atypical ambient conditions comprising an ambient temperature of 87.2 °F with a wind speed of 10 mph from varying directions in a full 360° arc centered around the facility

# Base Case – South Site

## Plan View

Section  
3




*Solution Time 275 (s)  
Temperature (F): 87.2  
Windspeed (mph): 10.0  
Prevailing Wind Direction (deg): 95*

*Note: The extended plumes seen in the first few animation frames are due to a pre-calculated approximate solution used to seed the model initial conditions*

# Base Case – South Site

## Isometric View

Section  
3



*Solution Time 275 (s)*  
*Temperature (F): 87.2*  
*Windspeed (mph): 10.0*  
*Prevailing Wind Direction (deg): 95*

Note: The extended plumes seen in the first few animation frames are due to a pre-calculated approximate solution used to seed the model initial conditions

## **Analysis & Conclusions:**

- The intent of the study is to assess the expected distribution of air temperatures surrounding the Project Double Reed sites due to concern that the heated air exhausted from the rooftop equipment may potentially adversely effect nearby environmental conditions
  - This CFD simulation describes the steady operation of heat generating equipment serving two large data center sites, comprising a total of three facilities
    - The typical equipment for each building is comprised by 60 air-cooled chillers, 6 DOAS units, 9 RTUs, 88 condensing units, and 84 transformers
    - The emergency propane generators are not included in the model as they serve only as life-safety emergency systems and will not be used during normal operating conditions except for regular testing and maintenance, such that their inclusion within the model is not expected to result in any significant deviation from the expected typical plume dispersion as reported
- To reasonably simplify the computational model, the STAMP site was split into two separate 1 sq mile domains
  - The distance between the Project Double Reed sites is approximately 0.5 miles and so the exhaust plumes are not expected to positively compound with one another across the two sites
- As a reasonable “worst-case” scenario, the simulated ambient temperature is set to be 87.2 °F which aligns with the equipment sizing design condition and exceeds the ASHRAE 99.6% cooling design condition of 86.6 °F as measured from the nearby Buffalo Niagara International Airport

*Analysis and Conclusions continued on to following slide...*

## **Analysis & Conclusions (Continued):**

- A wind speed of 10 mph was simulated based on wind condition data measured from the Genesee County Airport which is located nearby in Batavia, NY
  - This wind speed was selected from typical July wind conditions as July is the month with typically the highest average temperatures
  - A wind speed of 10 mph is modeled instead of the average wind speed of 7.4 mph to partially account for wind gusts
  - The wind was indexed at 30° increments around each site, comprising a full 360° arc, from 5° to 335°
- The animated plume dynamics from each site describe that the ambient air temperatures at both ground level and at approximately 50 ft above grade may rise above approximately 1 °F only in the vicinity immediately adjacent to the facilities
  - However, this effect is highly localized and drops off substantially with distance from either site such that it is not expected to materially effect the environmental conditions around the facility sites themselves and therefore is also not expected to adversely affect environmental conditions outside of the STAMP site
  - It was also noted that there is a parcel of land at the north side of the STAMP site which interrupts the typical site perimeter and so is located relatively nearer to the north Project Double Reed site than other property locations
    - The animated plume dynamics of the north site appear to indicate that the northern parcel may experience above ambient temperature exhaust but the visualized plume is well elevated into the atmosphere due to its buoyancy such that this property is not expected to sustain a direct impact on environmental conditions at the ground or housing level
      - The current results indicate that only slightly above ambient temperature air from the north site facility may periodically sweep over the northern parcel for strong southern prevailing winds