

**STAMP Onsite Wastewater Treatment Facility**  
**Basis of Design Report**  
**For The**  
**Genesee County Economic Development Center**



**June 2020**  
**Updated December 2020**  
**Updated August 2021**  
**Updated October 2021**  
**Updated December 2021 for FM**  
**Updated January 2022 for WWTF**  
**Separated into FM & MPS and WWTF Reports January 2022**



# Table of Contents

	<b>Page</b>
I. General .....	1
A. Background.....	1
B. Purpose.....	2
Onsite WWTF .....	3
II. Project Information .....	3
A. Site Location.....	3
B. Design Flows .....	4
C. Design Loadings .....	4
D. Design Water Quality Treatment Limits.....	4
III. Proposed Design .....	6
A. Headworks .....	7
B. Distribution Structure .....	7
C. Treatment Tanks .....	8
D. Aeration Blowers (SBRs).....	9
E. Coagulation Flocculation Tank .....	9
F. Filter Building.....	9
G. Disinfection.....	10
H. Screw Press Dewatering .....	10
I. Site & General Facility .....	11
J. Odors.....	11
K. Chemical Storage.....	11
IV. Phasing of Construction Discussion .....	12
V. Operations .....	15
A. Facility Operations.....	15
B. Emergency Response.....	15
VI. Conclusion.....	16

## Figures

- Figure 1      STAMP Site Location Map
- Figure 2      Proposed FM Route
- Figure 3      Overall STAMP Site Plan
- Figure 4      MPS and WWTF Site Plan
- Figure 5      WWTF Process Flow Diagram

## **Appendices**

Appendix A Wet Well Calculations

Appendix B Force Main System Curves

Appendix C Draft SPDES Discharge Permit Limits

Appendix D Design Calculations & Equipment Selection

1. Mechanical Bar Screen, Washer Compactor
2. Influent Flow Meter
3. Sequential Batch Reactor (SBR) Design Calculations
4. Sludge Holding Tank (SHT) Design Calculations
5. SBR Aeration Blowers
6. SHT Aeration Blowers
7. Disc Filter Sizing and Equipment Selection
8. Coagulation and Flocculation Tank Design
9. UV Disinfection Sizing and Equipment Selection
10. Screw Press Sizing and Equipment Selection
11. Sanitary Sewer Pump Selection

## Acronyms

10SS	Ten States Standards
BOD <sub>5</sub>	5-day biochemical oxygen demand
FM	Force main
GCEDC	Genesee County Economic Development Center
GEIS -	Generic Environmental Impact Statement
GPD -	Gallons per day
HDD -	Horizontal directional drilling
HDPE -	High-density polyethylene pipe
ICEAS -	Intermittent Cycle Extended Aeration
MGD -	Million gallons per day
MOU -	Memorandum of Understanding
MPS -	Main pump station
NYSDEC -	New York State Department of Environmental Conservation
PLC -	Programmable Logic Controller
SBR -	Sequential Batch Reactor
SEQR -	State Environmental Quality Review Act
SGIS -	Smart Growth Impact Statement
SHT -	Sludge holding tanks
SPDES -	State Pollutant Discharge Elimination System
STAMP -	Western New York Science & Technology Advanced Manufacturing Park
TDH -	Total dynamic head
TKN -	Kjeldahl nitrogen
TP -	Total phosphorus
TSS -	Total suspended solids
USFWS -	U.S. Fish and Wildlife Service
VFD -	Variable frequency drive
WWTF -	Wastewater Treatment Facility

## **I. General**

### **A. Background**

The Genesee County Industrial Development Agency d/b/a/ the Genesee County Economic Development Center (GCEDC) and its affiliate, the Genesee Gateway Local Development Corporation (GGLDC), have been working for the last several years on the development of the Western New York Science & Technology Advanced Manufacturing Park (STAMP). The Site is planned as an advanced manufacturing campus on approximately 1,262 acres of land in the Town of Alabama, New York located along the west side of New York State Highway 77/63 (north of Judge Road) approximately five miles north of the I-90/New York State Thruway (STAMP Site).

At full build out, STAMP will be a high technology campus with the potential to accommodate over 6 million square feet of advanced technology manufacturing and related uses and to create up to 10,000 jobs. The GCEDC, as lead agency pursuant to the State Environmental Quality Review Act (SEQR), prepared a Generic Environmental Impact Statement (GEIS) and a Smart Growth Impact Statement (“SGIS”) that analyzed the potential impacts of STAMP pursuant to the requirements of the SEQR and the State Smart Growth Public Information Policy Act.

In January 2012, the Final GEIS for STAMP was accepted as complete. The FGEIS identified alternatives for wastewater treatment for STAMP and assumed a maximum of 3 million gallons per day (MGD) of sanitary discharge would be needed. The preferred treatment alternative at that time included an onsite Wastewater Treatment Facility (WWTF) with a discharge to either Oak Orchard Creek, Whitney Creek or Tonawanda Creek. Based on feedback received during the GEIS process, several meetings with the neighboring Tonawanda Seneca Nation, and changes in the development of the STAMP Site to focus on the semiconductor industry, new alternatives for treatment were developed.

In August of 2013, a Conceptual Water and Wastewater Alternatives Analysis and Recommendations Report identified potential sanitary sewage conveyance and treatment options for the STAMP project, including 1.0 million gallons per day (MGD) of sanitary sewer effluent and 11.0 MGD of industrial process wastewater. Based on this report, the Village of Medina Wastewater Treatment Facility (Medina WWTF) was selected as the preferred sanitary sewer effluent treatment alternative.

The Tonawanda Seneca Nation voiced concerns with discharging effluent to Whitney Creek which flows into the Tonawanda Creek. The Tonawanda Creek flows through the Tonawanda Seneca Nation and it is an essential part of their cultural heritage. Another concern expressed by the New York State Department of Environmental Conservation (NYSDEC) was discharges to Whitney Creek and how that could affect the hydrology of the Tonawanda Wildlife Management Area. By utilizing the Medina WWTF and connecting to an established collection system, potential effects associated with discharging to Whitney Creek or directly to the Tonawanda Creek could be avoided.

A Memorandum of Understanding (MOU) was developed between the Village of Medina and the GCEDC which outlined the process of analyzing potential discharge routes through the Village, analyzing potential capacity upgrades at the Medina WWTF, and overall project implementation and ownership. However, in May 2017, the MOU with the Village expired so other means of wastewater disposal was deemed necessary. Additionally, by utilizing onsite recycling for the industrial process water, the overall potential total volume of wastewater has decreased significantly from 12 MGD to 6 MGD, causing a change in the proposed treatment methods and discharge location. More importantly, as noted in the 2013 Conceptual Water and Wastewater Alternatives Analysis and Recommendations Report, the need for a potential future large diameter force main “big sewer” for the disposal of process water is no longer needed.

With a reduced wastewater discharge maximum requirement of 6.0 MGD, onsite alternatives were once again considered feasible. Offsite effluent discharge locations were reviewed and analyzed as part of an ongoing effort to minimize environmental impacts and overall project costs for the overall wastewater solution. The review included input from the NYSDEC. Oak Orchard Creek near NYS Route 63, just north of the Iroquois Wildlife Refuge, was determined to be the preferred discharge location.

Several layout options were considered for an onsite WWTF, onsite pump station, and offsite discharge location. The preferred alternative involves an onsite Sequential Batch Reactor (SBR) sanitary sewer treatment facility that will discharge effluent to an onsite wastewater pump station. The WWTF will be designed to be easily expandable at treatment capacity levels of 0.25, 0.50, and 1.0 MGD. The onsite wastewater pump station involves a pump station and force main sewer that will collect, and discharge treated manufacturing process wastewater effluent and treated effluent from the onsite WWTF. The pump station will be designed to be easily expandable at capacity levels of 3.0, 4.5, and 6.0 MGD. The STAMP team is currently working through the permit process with the U.S. Fish and Wildlife Service (USFWS) for the offsite force main and has begun design and permitting efforts for the onsite WWTF.

## **B. Purpose**

A new onsite wastewater treatment facility (WWTF) will be constructed to treat the sanitary wastewater generated by the manufacturing tenants. The process wastewater generated by the tenants will be treated at the tenants’ facilities. After treatment, the effluent flow from the onsite WWTF and the treated process wastewaters will be combined at the main pump station (MPS) wet well and then pumped to the discharge location in Oak Orchard Creek, north of Shelby Center in Orleans County through a force main (FM).

This report will outline the design of the FM, MPS, and the onsite WWTF, as well as describe the basis of design for the equipment and treatment processes. All work was designed within the accepted criteria of the Recommended Standards for Wastewater Facilities, 2004 Edition (commonly referred to as the “10 States Standards”) and TR-16 Guides for the Design of Wastewater Treatment Works (referred to as “TR-16”).

## Onsite WWTF

### **II. Project Information**

To provide wastewater treatment for the STAMP site, an Onsite WWTF will be constructed. Several treatment options were considered, and the preferred alternative is a Sequential Batch Reactor (SBR) sanitary sewer treatment facility that will discharge effluent to an onsite wastewater pump station. The WWTF will be designed to be easily expandable.

The alternatives for the Onsite WWTF at the STAMP site were evaluated considering upfront capital costs, long term operation and maintenance (O&M) costs, and constructability. The chosen SBR technology is a continuous flow, intermittent cycle extended aeration system (ICEAS). This system is modular and suits the phasing needs of the STAMP site. The alternate treatment technologies considered include MBR technologies, fixed film technologies, and conventional activated sludge systems. The MBR technology proved to have a large maintenance expense associated with replacing the membranes at the end of their useful life. Additionally, the STAMP facility is meant to be operated with as little manpower as possible and an MBR system will require regular cleaning and backwashing tasks while the cycling operation of the SBR will be controlled by a programmable logic controller (PLC). Fixed film technologies were not ideal for the site because of the large footprint that they would need to meet the strict nutrient limit requirements. Fixed film technologies create sloughing of the biofilm which would need to be clarified and potentially filtered to meet the strict solids requirements of the site, the SBR technology does not require an additional clarifier because the biosolids are removed from the effluent within the treatment basin by the settling phase of operation. The closest technology to an SBR would be a conventional activated sludge system. These systems require both primary and secondary clarification and include recycling the biomaterials to the treatment basin. This alternative was not chosen because of the added infrastructure of the clarifiers and the hands-on operation that it would require.

The SBR plant consists of concrete tanks and associated treatment equipment including aeration blowers, pumps, submersible mixers, and process equipment. The infrastructure installed for the initial phases will be designed to be expandable to treat increasing wastewater flows. Therefore, the initial construction will avoid wasteful investments and will be necessary to provide treatment for the greater wastewater flows generated during the later phases of the park build-out.

#### **A. Site Location**

The existing STAMP Site consists of agricultural land located within the Town of Alabama (Town). The location of the proposed STAMP Site including the location of the onsite WWTF is shown in Figure 1.

## B. Design Flows

The sanitary wastewater produced at the STAMP Site will increase incrementally as the STAMP Site is developed. Therefore, the WWTF will be built in phases in response to these increasing flows. The design flow average was determined from the expected occupancy of the STAMP site at full build. The STAMP site is expected to support approximately 10,000 employees. Considering a per capita usage rate of 35 gpd and a peaking factor of 2x for a new collection system, this would require a treatment capacity of 700,000 gpd. Including the 100,000 gallons per day (GPD) of treatment capacity allocated to the Town for future use and a factor of safety of 1.25 gives us the full build design average daily flow of 1 MGD. Additionally, a peaking factor of 2x is considered to arrive at a peak design flow. The full-build WWTF described in this report will be able to treat the expected design flow rates. The design flow rates are described in the table below.

### DESIGN FLOW RATE

Average Daily Flow	1.0 MGD
Peak Flow	2.0 MGD

## C. Design Loadings

The sanitary wastewater produced at the STAMP Site is anticipated to have typical sanitary wastewater characteristics. The WWTF will be designed to treat the influent concentrations and loadings of contaminants. The table below summarizes these contaminants including 5-day biochemical oxygen demand (BOD<sub>5</sub>), total suspended solids (TSS), total Kjeldahl nitrogen (TKN), ammonia, and total phosphorus (TP). The loadings were determined from the design average daily flow of 1.0 MGD.

### DESIGN INFLUENT CONTAMINANT CONCENTRATIONS AND LOADINGS

Contaminant	Concentration (mg/L)	Loading (lbs/d)
BOD <sub>5</sub>	300	2502
TSS	250	2085
TKN (as N)	60	500
Ammonia (as N)	40	334
TP (as P)	4	33

## D. Design Water Quality Treatment Limits

The New York State Department of Environmental Conservation (NYSDEC) has provided draft State Pollutant Discharge Elimination System (SPDES) permit limits based on water quality in

Oak Orchard Creek near the proposed discharge location. The WWTF is designed to remove the influent contaminants to meet these discharge permit limits at the design flow rate. The table below summarizes some parameters from these limits. Complete draft SPDES permit limits are provided in Appendix C.

**SELECTED SPDES DRAFT PERMIT LIMITS**

<b>Parameter</b>	<b>Limit</b>
Flow Rate	1.0 MGD
pH	6.0 - 9.0 S.U.
BOD5	5.0 mg/L
TSS	10 mg/L
Ammonia (as N)	1.2 mg/L, Summer
	1.9 mg/L, Winter
TP (as P)	0.20 mg/L
Fecal Coliform	200 CFU/100mL

These limits include very low phosphorus discharge limits and fecal coliform removal requirements. Therefore, the WWTF will include a disc filter to remove phosphorus and a UV system to provide effluent disinfection.

### III. Proposed Design

The WWTF will utilize a continuous flow ICEAS SBR process, as well as disc filters, and a UV disinfection system to treat sanitary wastewater. This biological treatment process is suited to accept sanitary wastewater and biological waste streams such as from food processing plants. The facility will also include a screw press to dewater solids for final landfill disposal. The process design calculations and proposed equipment are provided in Appendix D. The site plan and process flow diagram can be found in Figures 4 and 5, respectively.

The STAMP sewer collection system will flow by gravity to convey wastewater from the STAMP tenants to the WWTF. The STAMP gravity sewer will enter the WWTF site approximately 15 ft below grade. Therefore, the wastewater will need to be lifted to grade to flow through the treatment process. The STAMP gravity sewer would be extended to connect to the influent wet well where submersible pumps will lift the wastewater to grade allowing flow by gravity to occur through the remaining system. After the influent wet well, wastewater will flow through a mechanical bar screen, which will remove large particles and debris. It will then flow to a distribution box which will evenly distribute the flows to the SBR basins.

The SBRs operate in sequences of batch treatment cycles beginning with aeration, then settling, and decanting. During the aeration cycle, oxygen is added for bacteria to consume the contaminants within the wastewater. The air is then turned off to allow the bacteria to settle to the bottom of the tank. This allows treated effluent to be decanted from the end of the SBR basins.

To remove phosphorus a coagulating agent such as aluminum sulfate will be added to the SBR to precipitate out phosphorus. This chemical will be stored in a chemical bulk storage area located in the headworks and control building. The chemical bulk storage areas will include spill prevention measures including double containment equal to the largest storage volume per NYSDEC bulk storage requirements.

Additionally, following the SBR, effluent will enter a coagulation flocculation basin where coagulant and polymer will be added to aggregate the precipitated phosphorus into larger flocculent particles. The coagulation flocculation effluent would then be filtered through a disc filter to remove the precipitated and flocculated phosphorus to the required discharge levels. The clear effluent would then flow through a UV disinfection system before discharge to the MPS wet well on the STAMP site.

The biomass removed from the SBR basins will be pumped to the aerated sludge holding tanks (SHT). A dewatering building will be constructed to press the sludge to a higher solids concentration. This material can then be disposed of through solids hauling to a landfill.

The proposed designs are in accordance with the standards specified in 10 States Standards as well as *TR-16*. Automatic effluent sampling will occur in the effluent box after the UV system, prior to discharging to the MPS wet well. This sampling location was chosen because, after disinfection, the water will be treated to SPDES permit requirements. The disinfection requirement is seasonal. When disinfection is not required, the UV lamps will be turned off and the effluent at this location will still be treated to the permit requirements before final discharge to the MPS wet well.

## **A. Headworks**

The headworks will include the influent wet well and the influent channel which will include the bar screen and laser flow meter to measure the influent flow rate. The flow will then proceed to the distribution structure which will distribute flows evenly to the SBRs. The headworks equipment will be installed within the headworks and control building which will also include the chemical bulk storage facilities, see below, and the process equipment to operate the SBRs including the aeration blowers. The headworks and control building will also house the controls for the SBRs and will serve as the operations center of the facility.

### **Influent Wet Well**

The influent pipe will connect to the 10-foot manhole wet wells which will house submersible pumps to lift the influent flows to the influent channel at grade. One manhole will be installed initially, and the pumps will be expandable in response to increasing wastewater flows as the STAMP Site is developed.

### **Bar Screen**

A new bar screen will be installed within the concrete influent channel to remove large particles and debris. The bar screen is designed for flows of 2.0 MGD and includes 1/4" wide bars with 1/4" openings, set at a 30-degree angle as specified in Sections 61.121 and 61.122 of 10 State Standards. The bar screen is automatically cleaned by a rake conveyor operated by a 1/2 HP premium efficiency motor and variable frequency drive (VFD).

The influent channel is rectangular at 1' – 6" wide and 4' deep with a bottom slope of 1%. Therefore, the approach velocity within the channel at the average and peak design flows will be 2.6 ft/s and 3.4 ft/s. The velocity for the design peak flow is above the recommended 3 fps; however, the STAMP site will have a new collection system with little inflow and infiltration, so the peak design event is expected to occur infrequently and not for sustained periods of time. The corners of the channel include fillets to prevent solids accumulation.

### **Washer Compactor**

The screenings will be emptied into a washer compactor. The washer compactor is designed to accept debris up to 4", including clothes, metal, wood, concrete and other harsh materials. Operating on a 3/4 HP premium efficiency motor, the compactor will reduce the volume of trash and solids by more than 80% and will be run on variable speed drives (VFDs) to limit electric usage and operate more efficiently. The washer compactor will compact the screenings and will provide water to wash the screening to reduce odors.

## **B. Distribution Structure**

Following the headworks, wastewater will flow into a distribution structure which will include chambers that distribute the flows evenly to the SBR treatment tanks. The chambers will include slide gate valves to isolate the flows from the SBRs for maintenance.

## C. Treatment Tanks

### Sequential Batch Reactors

The facilities will be constructed with two SBR plants, each treating 0.5 MGD. Each plant will consist of three rectangular concrete tanks. The SBRs will utilize the Intermittent Cycle Extended Aeration (ICEAS) process which is a continuous flow biological treatment method which combines multiple treatment processes into one tank. The process is automatic and combines the aeration system, blowers, pumps, mixers, effluent decanter and monitoring via one control system. The process does not require primary or secondary settlement tanks or return sludge pumping like traditional activated sludge facilities. Influent flow is distributed to all three SBR tanks where any flow or loading variations are evenly spread across the tanks.

The 30' wide by 86' long SBR tanks will have a side water depth of 15'. A 12" thick precast concrete pre-react wall, located 11' – 11" from the influent end of the tanks will be constructed within each SBR tank to create a pre-react zone. Each pre-react wall will contain seven (7) 18" square openings located at the bottom to allow flows to exit the pre-react zone to the treatment portion of the tank. PVC aeration piping containing fine bubble diffusers will be installed along the entire bottom of the tank. The fine bubble diffusers consist of 9" diameter EPDM discs. The tanks will be partially buried, utilizing catwalks along the top of the tank for access to the equipment and pumps in the tanks. A new aluminum staircase will be installed leading up to the catwalk. At the effluent end of the SBR tanks will be a mechanically driven stainless-steel decanter which consists of an adjustable weir to allow the upper portion of the settled wastewater to be removed while also keeping out any floatable materials.

The SBRs will be operated in batches. Wastewater will enter the pre-react zone where air will be continuously provided at a high rate to oxygenate the wastewater and provide for enhanced organics removal before proceeding to the treatment portion of the SBR tanks. During normal average daily flows, the SBRs will aerate for 2 hours where biological oxidation and reduction occurs. After this period, the air will be shut off to the SBR via an actuated valve, and the aeration and mixing process will cease for one hour which allows the solids to settle to the bottom of the tank. This occurs while influent wastewater continues to flow into each SBR. After an hour of settling time, the decanter weir is slowly lowered for treated wastewater to flow to the effluent piping.

After water has been drawn down to a specified level, based on capacity designs, the decanter rises, and the aeration and mixing process begins again. During periods of wet weather and high flows the control system automatically enters the storm mode where each decant cycle operates for 75% of the normal cycle time to increase treatment capacity.

### Sludge Holding Tanks

The tanks will be sectioned at the influent end of the tanks for the sludge holding tanks (SHTs). Settled sludge will be removed from the SBR tanks using submersible solids handling pumps and discharged into the SHTs. The pumps will be mounted to rails on the side of each SBR tank and will operate for a pre-determined time and frequency based on the accumulated sludge level. The

SHTs will be aerated with fine bubble diffusers to prevent the sludge from becoming anaerobic. Sludge will be allowed to settle and thicken with the supernatant being removed from the SHTs and returned to the head of the plant. This thickened and digested sludge will then be removed from the SHTs using submersible solids handling pumps and sent to the screw press for dewatering.

The SHT calculations shown in Appendix D are for the biomass produced from both 3-basin SBR tanks. After approximately 30 days of storage, the expected sludge production from the full-build facility is 12,687 GPD which will be dewatered by the screw press.

#### **D. Aeration Blowers (SBRs)**

Aeration for the SBRs will be provided by positive displacement blowers installed within the headworks and controls building. Six 30-HP blowers will aerate the SBRs while six 25-HP blowers will aerate the SHTs with two redundant SHT blowers. The blowers will utilize premium efficiency motors and VFDs to control the amount of airflow delivered to the SBRs under a wide range of flow conditions. Dissolved oxygen sensors located within each SBR and local control panels will monitor the dissolved oxygen content and be used to automatically adjust the amount of air delivered to each SBR using an actuated butterfly valve. Blowers will also be provided for the SHTs.

#### **E. Coagulation Flocculation Tank**

Alum will be added in the SBRs to start the phosphorus precipitation process. Some phosphorus will be settled out of the wastewater, but further removal will be required to meet the proposed discharge limits. Following the SBRs the treated effluent will flow through a magnetic flow meter and into a segmented coagulation flocculation tank. Additional alum and polymer will be added in the rapid mix portion of the tank in proportion to the measured flow rate. The rapid mix tank will thoroughly mix the chemical into the water before flowing into the coagulation portion of the tank. The coagulation portion will be mixed at a slower speed with a paddle mixer to promote aggregation of the precipitated phosphorus particles into larger flocs. The final flocculation portion of the tank will be mixed at an even slower speed than the rapid mix and coagulation portions to promote larger floc formation. The segmented tanks are sized to provide a ½ minute, 5 minutes, and 5 minutes of contact time for the rapid, coagulation, and flocculation tanks, respectively, at the design flow rate.

#### **F. Filter Building**

To achieve the required discharge limits of effluent phosphorus, disc filters will be installed following the coagulation flocculation tank. The disc filters will provide further removal of precipitated phosphorus and particles from the water. These disc filters will be installed within a concrete block building. The filters will bring the TSS levels below 10 mg/L and the total phosphorus levels below 0.20 mg-P/L. The design sheet in Appendix D shows the design parameters for one of the two filters. This demonstrates that the filters are capable of treating the design and peak flows from 1.0 mg-P/L, which is greater than the expected discharge from the SBRs, to the required 0.2 mg-P/L.

Inside the filters, influent water enters between a pair of discs and water passes outward across the discs. The filtered water then flows by gravity into a common collection well and exits the unit through the outlet pipe. The filtering discs are constructed of a woven polyester filter cloth as the filtration medium. As water passes across the discs, solids accumulate on the disc surface, which creates head loss. This causes the water level inside the unit to increase. When the water reaches a certain level, a level sensor activates an automatic spray wash cleaning sequence. The filter units will be expandable to allow for increasing numbers of discs to be installed in response to increasing wastewater flows as the tenants occupy the site.

Each disc has its own spray header to ensure efficient disc cleaning. The spray wash water (backwash reject) from each set of discs is collected in a common channel and then purged from the unit through a stainless-steel drain valve. The reject water will flow by gravity to a pump station which will pump the filter backwash back to the head of the plant.

## **G. Disinfection**

Following the disc filters a UV disinfection system will be installed to inactivate any microorganisms and viruses still in the treated water to meet the effluent disinfection requirements. The magnetic flow meter installed previous to the coagulation flocculation tank will communicate with the UV system for dose pacing. The UV structure will contain a concrete channel with a serpentine weir near the outlet of the structure. The weir is used to maintain a constant water level within the channel, guaranteeing that all UV bulbs are submerged at all times.

The main components of a UV disinfection system are the arc lamps, a reactor, and ballasts. The UV equipment will be installed within the channel. The system will include expandable modules which will allow installation of increasing amounts of UV lamps in response to increasing wastewater flows as the STAMP Site is developed.

The proposed system utilizes low pressure, high output lamp technology in accordance with energy efficiency best practices. This system will contain two banks of UV lamps to provide redundancy. The UV system will provide a UV dose of 30 mJ/cm<sup>2</sup> at the peak design flows per standards. The system is sized to treat the peak design flow considering a 65% UV transmittance with one bank out of service, providing 100% redundancy. This is accomplished with 64 lamps as detailed in Appendix D.

Due to grading of the site and the required slopes and depths of the effluent pipe system, the UV channel will be housed within a recessed concrete structure. All critical electrical panels will be placed at grade level, rather than in the vault to avoid potential damage in the event of a backup. A small davit crane will be installed to help lift the modules from the channel.

## **H. Screw Press Dewatering**

The screw press machines will be installed in the dewatering building. The screw press will be installed above a recessed sump with grated flooring and drain for wash down of the machine. The screw press will be fed from the submersible pumps in the SHTs. The motion of the screw will

increase the pressure of the sludge against the screen to dewater the material. The screw press drive and the filtrate recycle pump will be operated on VFDs.

The screw press will be able to process the sludge and will be able to dewater to greater than 20% total solids with 95% solids capture. The system includes a filtrate recycle system to ensure solids capture. An emulsion polymer make-down unit will meter polymer to an injection device adding polymer to the sludge before the screw press.

During pressing, the exterior of the screen is continually washed and following pressing, the screen is washed down. The filtrate will exit the machine from the bottom and will flow through the drain in the sump to the dewater return line to the head of the plant. The dewatered material will empty into a container that will be hauled from the site for final disposal at a landfill.

The expected sludge production from the full-build facility is 12,687 GPD. The feed pump and screw press are capable of processing sludge at 44 gpm which would process the daily sludge production in less than 5 hours. The dewatered sludge will be hauled off site to be disposed of in a landfill.

## **I. Site & General Facility**

A new asphalt driveway will be installed around the WWTF Site to provide access to the buildings and tanks. The new driveway will connect to the access road to the north of the site. A new generator will be installed on site and connected to the facility in order to provide backup power.

## **J. Odors**

The treatment processes where odors are a concern are contained within buildings to mitigate odors. The only location where raw, untreated wastewater will be exposed to the atmosphere is enclosed within the headworks and control building. The SBR process and aerated sludge process will not produce strong odors. The dewatering process, where aerated sludge is dewatered, will be enclosed within the dewatering building and the material will be immediately removed from the site to the landfill for final disposal following dewatering.

## **K. Chemical Storage**

The chemicals stored on site will include alum for phosphorus precipitation and polymer for screw press dewatering. The alum will be stored in a chemical bulk storage area located in the headworks and control building. The polymer will be stored in a chemical bulk storage area in the dewatering building. The chemical bulk storage areas will include spill prevention measures including double containment equal to the largest storage volume per NYSDEC bulk storage requirements.

#### IV. Phasing of Construction Discussion

The report primarily focuses on the full build 1 MGD treatment plant because this is the flow rate for the full build of the STAMP site. However, the wastewater treatment requirements for the site will increase incrementally as the STAMP site becomes occupied. There is a wide range of possibilities for the incremental increases in wastewater needs and phasing depending on the type and size of tenant.

Therefore, the design of the design of the SBR has been carefully thought out to provide flexibility to respond to incremental increases in wastewater flows. This section of the report has been added as an example of how this phasing might occur. This is not the planned phasing for the project, but it highlights the flexibility and modularity of the chosen SBR treatment technology and why it is suited for this application. At all phases, the treatment system will be capable of meeting the SPDES permit requirements.

As discussed, there is a wide range of possibilities for the pace and phases of wastewater needs as the park is occupied and the wastewater needs increase to the maximum design average daily flow of 1 MGD. The table below and the following discussion provides an example of the potential phasing of the project and the expected flows.

#### STAMP WASTEWATER FLOWS AND PHASING

Phase	Wastewater Flow Rate (GPD)
1	0 - 25,000
2A	250,000
2B	500,000
2C	750,000
3	1,000,000

#### Phase 1: 0 – 25,000 GPD

Phase 1 will consist of installing a precast influent wet well tank and pouring a concrete channel and pad to install the mechanical course bar screen. The bar screen will be built to treat the Phase 3 wastewater flows. To accommodate the low wastewater flows during Phase 1, a temporary, removable steel baffle, will be inserted into the channel. The blowers and controls will be installed in a temporary enclosure that will serve as a portion of the future full-build controls building. The control panel installed for Phase 1 is designed for the full build programmable logic controller (PLC) to accommodate the future expansion and required inputs.

The SBR and sludge holding tank (SHT) for Phase 1 will involve constructing two concrete basins which will serve as future SHTs for Phases 2 and 3. The walls will serve as common walls for the future SBR tank construction.

The disc filter following the SBRs will be installed within a disc filter building that will be large enough for the full-build disc filters. Initially, one filter unit will be installed with one disc. Filter discs can be added to this unit as flows increase.

The UV disinfection system will be installed in a concrete channel poured within a concrete vault. Similar to the bar screen, a temporary steel baffle will be installed to accommodate low flows. A metal sided enclosure would be constructed on top of the vault. The UV lamps to treat Phase 1 flows will be installed initially, and the channel will be large enough to accommodate the UV system to treat full-build flows.

The equipment for Phase 1 is as follows:

#### SBR/SHT Equipment

- (2) Positive displacement 20-HP SBR blowers (one duty, one standby used for future SHT)
- (1) Positive displacement 20-HP SHT blower
- (2) Fine bubble aeration grids (one per SBR and SHT)
- (2) Decanters with single drive units (one per SBR and SHT)
- (1) Automated air control valve
- (1) 3-HP submersible waste sludge pump (SBR)
- (1) 7.5-HP mixer (SBR)
- (1) Control package, including the following features:
  - 4-basin main control panel with HMI, motor starters and VFDs
  - DO control
  - Remote HMI accessibility

#### Additional Equipment

- (2) 10-HP influent wet well pumps
- (1) 1.5' wide ¼" mechanical bar screen
- (1) Disc filter unit. Initially installed with (1) disc. Polymer feed/coagulation system, backwash tank, and pumps sized for full-build
- (1) UV disinfection system with (16) lamps installed

#### **Phase 2A – 2C: 250,000 – 750,000 GPD**

The Phase 2A through Phase 2C infrastructure will add on to the infrastructure built during Phase 1. For Phase 2A, this will include constructing two large concrete basins for the SBR tanks. The walls of these basins will be tied into the two tanks constructed during Phase 1, which will now serve as the SHTs. Additional tanks and equipment would be added as flows increase for Phases 2B and 2C.

The dewatering building will be constructed during Phase 2A and will house a screw press sized for full build biosolids production. The disc filter unit will be expanded to add up to six additional filter discs as needed to treat additional flows. The UV disinfection system will be expanded to

treat additional flows by adding lamps. Additional lamps can be added up to the full build treatment capacity.

The equipment for the full-build of Phase 2C is as follows:

#### SBR/SHT Equipment

- (2) Positive displacement 50-HP SBR blowers (one duty, one standby)
- (2) Fine bubble aeration grids (one per SBR)
- (2) Decanters with single drive unit (one per SBR)
- (2) Automated air control valves
- (2) 3-HP submersible waste sludge pumps (one per SBR)
- (1) 7.5-HP mixer (mixer from Phase 1 SBR to be reused)
- (2) 3-HP submersible digested sludge pumps (SHTs)
- (1) Control package, including the following features:
  - HMI, motor starters and VFDs for two basin expansion (PLC from Phase 1)
  - DO Control
  - Remote HMI Accessibility

#### Additional Equipment

- (4) Influent wet well pumps
- (1) 12-in screw press including polymer feed system
- (6) Additional filter discs installed in Phase 1 disc filter unit
- (16) Additional UV lamps
- (1) Chemical feed system installed in control building

#### **Phase 3: 1,000,000 GPD (Full Build)**

Phase 3 will consist of constructing the additional concrete basins for the two SBR tanks and SHTs. These tanks can be constructed one at a time as wastewater flows increase. An additional disc filter unit with seven filter discs would be installed within the disc filter building to treat the full-build flows.

The equipment for Phase 3 is as follows:

#### SBR/SHT Equipment

- (1) Positive displacement 50-HP SBR blowers
- (2) Positive displacement 20-HP SHT blower
- (4) Fine bubble aeration grids (one per SBR and SHT)
- (4) Decanters with single drive unit (one per SBR and SHT)
- (2) Automated air control valves
- (2) 3-HP submersible waste sludge pumps (one per SBR)
- (2) 7.5-HP mixer (one per SBR)
- (2) 3-HP submersible digested sludge pumps (one per SHT)

- (1) Control package, including the following features:
  - HMI, motor starters and VFDs for two basin expansion (PLC from Phase 1)
  - DO Control
  - Remote HMI Accessibility

#### Additional Equipment

- (1) Disc filter unit with seven filter discs

## **V. Operations**

### **A. Facility Operations**

The Town does not have a municipal sanitary sewer collection or conveyance system. Therefore, the GCEDC intends to form a sewer-works corporation to own and operate all STAMP sewer infrastructure including the WWTF.

### **B. Emergency Response**

The local emergency management services such as fire departments and medical services will be trained for emergency safety and response at this facility. Specific procedures such as emergency startup of the backup generator and shutdown of specific equipment will be outlined, and training will be provided by the operators of the facility. The emergency management services will be taught the hazards of the chemicals stored on site. Diesel will be stored in a tank on-site for the emergency backup generator. This tank will be clearly marked, and the concerns will be defined for the emergency management services.

## **VI. Conclusion**

The offsite sanitary sewer project is an integral and critical part of the necessary infrastructure for the STAMP Site. The project design avoids and minimizes potential environmental impacts. The GCEDC is committed to providing safe and reliable wastewater treatment at the onsite WWTF and developing a facility that will meet the current and future needs of water quality and treatment capacity at the STAMP Site. These specific projects will be imperative in achieving these goals.

## **Figure 1**

### **General Location Map**

Referenced Drawings: None  
 Drawing Name: J:\PROJECTS\GCEDC\STAMP Offsite Sewer\Design\ACAD\Civil\Figures\Location Map May 2020.dwg  
 Date last accessed: 5/18/2020 3:33 PM  
 Date last plotted: 5/21/2020 8:12 AM  
 Plotted By: Nick Boyer




FIGURE 1

STAMP SITE GENERAL LOCATION MAP

WNY STAMP OFFSITE SEWER

TOWN OF ALABAMA AND TOWN OF SHELBY, NEW YORK STATE



205 ST. PAUL STREET, SUITE 500  
 ROCHESTER, NEW YORK 14604  
 TEL (800) 274-9000  
 FAX (585) 232-5836

**CPLteam.com**

ARCHITECTURE • ENGINEERING • PLANNING

DATE:	4/27/20
DRAWN:	ZLA
CHECKED:	ARK
SCALE:	AS NOTED
PROJ. #:	14822.00

## **Figure 2**

### **Proposed FM Route**

Referenced Drawings: None  
 Drawing Name: \\clarkpatrickerson.local\dfs\Projects\2\PROJECTS\GCEDC\STAMP Offsite Sewer\Design\CAD\Civil\Figures\Location Map May 2020.dwg  
 Date last accessed: 9/9/2020 8:02 AM  
 Date last plotted: 12/7/2020 11:29 AM  
 Plotted By: Andrew Kosa




FIGURE 2

FORCE MAIN GENERAL LOCATION MAP  
 WNY STAMP OFFSITE SEWER  
 TOWN OF ALABAMA AND TOWN OF SHELBY, NEW YORK STATE


205 ST. PAUL STREET, SUITE 500  
 ROCHESTER, NEW YORK 14604  
 TEL (800) 274-9000  
 FAX (585) 232-5836

**CPLteam.com**  
 ARCHITECTURE • ENGINEERING • PLANNING

DATE:	4/27/20
DRAWN:	ZLA
CHECKED:	ARK
SCALE:	AS NOTED
PROJ. #:	14822.00

## **Figure 3**

### **Overall STAMP Site Plan**



J:\PROJECTS\GCEDC\STAMP Onsite General\Design\ACAD\Civil\Site\Concept Plans\2020.01.28 MasterInfrastructureMap.dwg



# STAMP - MASTER BUILD OUT PLAN

WNY SCIENCE AND TECHNOLOGY ADVANCED MANUFACTURING PARK (STAMP)  
 JUNE 2020



## **Figure 4**


### **MPS and WWTF Site Plan**



## **Figure 5**


### **WWTF Process Flow Diagram**

Referenced Drawings: None  
 Drawing Name: J:\PROJECTS\GCEDC\STAMP Onsite WWTF\0 Design\ACAD\Civil\General\G-02\_STAMP\_WWTF\_PROCESS\_FLOW\_DIAGRAM.dwg  
 Date last accessed: 10/15/2021 8:52 AM  
 Date last plotted: 1/7/2022 5:16 PM  
 Plotted By: Nick Boyer



REVISIONS				
NO.	DATE	BY	CHKD	DESCRIPTION


 205 ST. PAUL STREET, SUITE 500  
 ROCHESTER, NEW YORK 14604  
 TEL (800) 274-9000  
 FAX (585) 232-5836  
**CPLteam.com**  
 ARCHITECTURE • ENGINEERING • PLANNING


 ANDREW R. K...  
 PROFESSIONAL ENGINEER  
 086962

**GENESSEE COUNTY ECONOMIC DEVELOPMENT CENTER**  
**(AGENCY SET, NOT FOR CONSTRUCTION)**  
 TOWN OF ALABAMA    GENESSEE COUNTY    NEW YORK STATE

DATE: 04/27/2020  
 DRAWN: MCZ  
 DESIGNED: NAB  
 CHECKED: ARK  
 SCALE: NTS

**STAMP ONSITE WASTEWATER TREATMENT FACILITY**  
**PROCESS FLOW DIAGRAM**

PROJECT NUMBER  
 14822.00  
 DRAWING NUMBER  
**FIG.-5**

THIS DOCUMENT IS THE PROPERTY OF CPLTEAM.COM AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM. WITHOUT THE WRITTEN PERMISSION OF CPLTEAM.COM, THIS DOCUMENT IS NOT TO BE USED FOR ANY OTHER PROJECT OR FOR ANY OTHER PURPOSE.

## **Appendix A**

### **Wet Well Calculations**

**Genesee County Economic Development Center  
WNY Science, Technology & Advanced Manufacturing Park (STAMP)  
Onsite Temporary Pump Station and Main Pump Station Wet Well Sizing**

**Temporary PS-Phase 1 (1 Pump Running, 1 Backup) 0.5 MGD  
Up to 0.50 MGD**

Wet Well Diameter	10	ft
Wet Well Top	669.5	ft
Wet Well Bottom	644	ft
Top of Operating Range	654	ft
Bottom of Operating Range	645	ft

Wet Well Volume	14981	gal
Operating Volume	5287	gal

Influent Flow Rate	347	gpm
Pump Flow Rate	900	gpm

Wet Well Fill Time	15.2	min
Wet Well Empty Time	9.6	min

**Permanent PS-Phase 3 (1 Pump Running, 1 Backup) 3.0 MGD  
Up to 4.0 MGD**

Wet Well Area	2250	ft
Wet Well Top	669	ft
Wet Well Bottom	652	ft
Top of Operating Range	658	ft
Bottom of Operating Range	655.5	ft

Wet Well Volume	286110	gal
Operating Volume	42075	gal

Influent Flow Rate	2082	gpm
Pump Flow Rate	2500	gpm

Wet Well Fill Time	20.2	min
Wet Well Empty Time	100.7	min

**Temporary PS-Phase 2 (2 Pump Running, 1 Backup) 1 MGD  
Up to 1.5 MGD**

Wet Well Diameter	10	ft
Wet Well Top	669.5	ft
Wet Well Bottom	644	ft
Top of Operating Range	654	ft
Bottom of Operating Range	645	ft

Wet Well Volume	29961	gal
Operating Volume	10575	gal

Influent Flow Rate	694	gpm
Pump Flow Rate	1388	gpm

Wet Well Fill Time	15.2	min
Wet Well Empty Time	15.2	min

**Permanent PS-Phase 4 (3 Pump Running, 1 Backup) 6.0 MGD  
Up to 6.0 MGD**

Wet Well Area	2250	ft
Wet Well Top	669	ft
Wet Well Bottom	652	ft
Top of Operating Range	658	ft
Bottom of Operating Range	655.5	ft

Wet Well Volume	572220	gal
Operating Volume	84150	gal

Influent Flow Rate	4164	gpm
Pump Flow Rate	4580	gpm

Wet Well Fill Time	20.2	min
Wet Well Empty Time	202.3	min

**Temporary PS-Phase 2a (3 Pump Running, 1 Backup) 1.5 MGD  
Up to 2.0 MGD**

Wet Well Diameter	10	ft
Wet Well Top	669.5	ft
Wet Well Bottom	644	ft
Top of Operating Range	654	ft
Bottom of Operating Range	645	ft

Wet Well Volume	29961	gal
Operating Volume	10575	gal

Influent Flow Rate	1041	gpm
Pump Flow Rate	1735	gpm

Wet Well Fill Time	10.2	min
Wet Well Empty Time	15.2	min

Note:


1. For the temporary pump station Phase 2 and Phase 3, each additional phase will be in addition to the previous phases.
2. When the sanitary and process water flows exceed 2.0 MGD the permanent Main Pump Station will be needed.
3. When the Main Pump Station is needed, the temporary pump station will be decommissioned.

## **Appendix B**

### **FM System Curve**

GCEDC  
STAMP OFFSITE SEWER

### GCEDC STAMP OFFSITE SYSTEM CURVES



## **Appendix c**

### **WWTF Draft SPDES Permit Limits**

## PERMIT LIMITS, LEVELS AND MONITORING

OUTFALL	LIMITATIONS APPLY	RECEIVING WATER	EFFECTIVE		EXPIRING
001	All Year otherwise stated	Oak Orchard Creek	See footnote (1)		ExDP

PARAMETER	EFFLUENT LIMITATION					MONITORING REQUIREMENTS				FN
	Type	Limit	Units	Limit	Units	Sample Frequency	Sample Type	Location		
								Inf.	Eff.	
Flow	Monthly Average	1.0	MGD			Continuous	Meter		X	
Flow	Daily Maximum	Monitor	MGD			Continuous	Meter		X	
pH	Range	6.5 – 8.5	SU			2/Day	Grab		X	
Temperature	Daily Maximum	90	° F			2/Day	Grab		X	
CBOD <sub>5</sub>	7-Day Average	Monitor	mg/L	Monitor	lb/d	1/Week	24-hr. Comp.		X	(2)
UOD	Daily Maximum	30	mg/L	250	lbs/d	1/Week	Calculated		X	(2,3)
Total Kjeldahl Nitrogen (TKN) (as N)	Daily Maximum	Monitor	mg/L	Monitor	lbs/d	1/Week	24-hr. Comp.		X	
Total Suspended Solids (TSS)	7-Day Average	15	mg/L	130	lb/d	1/Week	24-hr. Comp.		X	
Settleable Solids	Daily Maximum	0.1	mL/L			2/Day	Grab		X	
Dissolved Oxygen	Daily Minimum	5.0	mg/L			2/Day	Grab		X	(2)
Ammonia (as N) (June 1 – October 31)	Monthly Average	1.2	mg/L	10	lb/d	1/Week	24-hr. Comp.		X	(2)
Ammonia (as N) (Nov. 1 – May 31)	Monthly Average	1.9	mg/L	16	lb/d	1/Week	24-hr. Comp.		X	(2)
TKN	Monthly Average	Monitor	mg/l	Monitor	lb/d	1/Week	24-hr. Comp.		X	
Total Phosphorus (as P)	Monthly Average	0.5	mg/L	4.2	lb/d	1/Week	24-hr. Comp.	X	X	
Mercury, Low Level	Monthly Average	0.7	ng/L	-		Quarterly	Grab	X	X	(4)

EFFLUENT DISINFECTION		Limit	Units	Limit	Units	Sample Frequency	Sample Type	Inf.	Eff.	FN
Required Seasonal from May 1st - October 31st										
Coliform, Fecal	30-Day Geometric Mean	200	No./100 mL			1/Week	Grab		X	
Coliform, Fecal	7-Day Geometric Mean	400	No./100 mL			1/Week	Grab		X	
Chlorine, Total Residual	Daily Maximum	0.03	mg/L			2/Day	Grab		X	(5)

WHOLE EFFLUENT TOXICITY (WET) TESTING		Limit	Units	Action Level	Units	Sample Frequency	Sample Type	Inf.	Eff.	FN
WET - Acute Invertebrate	See footnote			0.30	TUa		See footnote		X	(6)

WET - Acute Vertebrate	See footnote			0.30	TUa		See footnote		X	(6)
WET - Chronic Invertebrate	See footnote			1.5	TUc		See footnote		X	(6)
WET - Chronic Vertebrate	See footnote			1.5	TUc		See footnote		X	(6)

## Footnotes Continued on Next Page

### Footnotes:

1. Upon construction completion, and submittal and acceptance by the DEC of the certificate of construction completion, **the final effluent limitations shall be effective upon DEC certification + 6 Months. The interim limits are monitor only until the final effluent limitations become effective** Both concentration and mass loading shall be reported for all parameters, except flow, settleable solids, pH, Temperature, DO and Fecal Coliform.
2. Limits may be reassessed upon a request to add new dischargers, either to the STAMP WWTP, or for a separate individual permit but whose discharge combines with the discharge of this permit and is discharged to outfall 001.
3. Ultimate Oxygen Demand (UOD) in mg/l shall be computed as follows:  $UOD = (1.5 \times CBOD_5) + (4.5 \times TKN)$ .
4. The permittee must sample and analyze for mercury using USEPA Method 1631E.
5. If no chlorine is used in the treatment process, then no total residual chlorine monitoring is required.
6. **Whole Effluent Toxicity (WET) Testing:**

Testing Requirements – Chronic WET testing is required, but report both the acute and chronic results. Testing shall be performed in accordance with 40 CFR Part 136 and TOGS 1.3.2 unless prior written approval has been obtained from the Department. The test species shall be Ceriodaphnia dubia (water flea - invertebrate) and Pimephales promelas (fathead minnow - vertebrate). Receiving water collected upstream from the discharge should be used for dilution. All tests conducted should be static-renewal (two 24-hr composite samples with one renewal for Acute tests and three 24-hr composite samples with two renewals for Chronic tests). The appropriate dilution series should be used to generate a definitive test endpoint, otherwise an immediate rerun of the test may be required. WET testing shall be coordinated with the monitoring of chemical and physical parameters limited by this permit so that the resulting analyses are also representative of the sample used for WET testing. The ratio of critical receiving water flow to discharge flow (i.e. dilution ratio) is 1.3:1 for acute, and 1.8:1 for chronic. Discharges which are disinfected using chlorine should be dechlorinated prior to WET testing or samples shall be taken immediately prior to the chlorination system.

Monitoring Period - WET testing shall be performed quarterly (calendar quarters) one year after the commencement of wastewater discharge beginning in January and lasting for a period of one full year and then after every five year.

Reporting - Toxicity Units shall be calculated and reported on the DMR as follows:  $TUa = (100)/(48\text{-hr LC50})$  [note that Acute data is generated by both Acute and Chronic testing] and  $TUc = (100)/(7\text{-day NOEC})$  or  $(100)/(7\text{-day IC25})$  when Chronic testing has been performed or  $TUc = (TUa) \times (10)$  when only Acute testing has been performed and is used to predict Chronic test results, where the 48-hr LC50, 7-day NOEC and/or IC25 are all expressed in % effluent. This must be done, including the Chronic prediction from the Acute data, for both species unless otherwise directed. For Chronic results, report the most sensitive endpoint (i.e. survival, growth and/or reproduction) corresponding to the lowest 7-day NOEC or IC25 and resulting highest TUc. For Acute results, report a TUa of 0.3 if there is no statistically significant mortality in 100% effluent as compared to the control. Report

a TUa of 1.0 if there is statistically significant mortality in 100% effluent as compared to the control, but insufficient mortality to generate a 48-hr LC50. Also, in the absence of a 48-hr LC50, use 1.0 TUa for the Chronic prediction from the Acute data, and report a TUc of 10.0.

The complete test report including all bench sheets, statistical analyses, reference toxicity data, daily average flow at the time of sampling and other appropriate supporting documentation, shall be submitted within 60 days following the end of each test period with your WET DMR and to the [WET@dec.ny.gov](mailto:WET@dec.ny.gov) email address. A summary page of the test results for the invertebrate and vertebrate species indicating TUa, 48-hr LC50 for Acute tests and/or TUc, NOEC, IC25, and most sensitive endpoints for Chronic tests, should also be included at the beginning of the test report.

WET Testing Action Level Exceedances - If an action level is exceeded then the Department may require the permittee to conduct additional WET testing including Acute and/or Chronic tests. Additionally, the permittee may be required to perform a Toxicity Identification/Reduction Evaluation (TI/RE) in accordance with Department guidance. Enforceable WET limits may also apply. The permittee shall be notified in writing by their Regional DEC office of additional requirements. The written notification shall include the reason(s) why such testing, TI/RE and/or limits are required.

DRAFT

## **Appendix D**

### **WWTF Basis of Design Equipment Selection**

1. Mechanical Bar Screen, Washer Compactor
2. Influent Flow Meter
3. Sequential Batch Reactor (SBR) Design Calculations
4. Sludge Holding Tank (SHT) Design Calculations
5. SBR Aeration Blowers
6. SHT Aeration Blowers
7. Disc Filter Sizing and Equipment Selection
8. Coagulation and Flocculation Tank Design
9. UV Disinfection Sizing and Equipment Selection
10. Screw Press Sizing and Equipment Selection
11. Sanitary Sewer Pump Selection

# **Mechanical Bar Screen, Washer Compactor**

**Date:** June 12, 2019

**Project:** STAMP WWTP Medina NY

**Proposal Number:** P10211

## BUDGET EQUIPMENT SCOPE

**To:** STAMP WWTP Medina NY

**From:** Your Duperon<sup>®</sup> Team

Dan Satryano  
Sales Project Manager  
(989) 754-8800  
dsatryano@duperon.com

**Rep:** Wayne Dodsworth  
Sales Engineer  
Koester Associates, Inc.  
(315)6973800  
wayned@koesterassociates.com

Lorene Bruns  
National Sales Manager  
(989) 754-8800  
lbruns@duperon.com



**Date:** June 12, 2019

**Project:** STAMP WWTP Medina NY

**Proposal Number:** P10211

## BUDGET EQUIPMENT SCOPE

**Thank you** for considering **Duperon**® system solutions for your project. We appreciate the opportunity to provide you with a **Budget Equipment Scope**. Please do not hesitate to contact your **Duperon**® Team with any questions as we work with you through the design process and ensure a successful project.

### Equipment Scope

#### SCREENS:

QTY	UNIT	DESCRIPTION
1	EA	<b>Duperon® FlexRake® - Front Clean Front-Return</b> Model: LF - LowFlow Enclosure (& Material): Fully Enclosed (304) Channel Width x Height: 1.5 x 4 Feet Clear Opening Size: 0.25 in Angle of Installation: 30 Deg. from Vertical Material Construction: 304 SSTL

Notes: Based on 4ft channel height. Please note the Low Flow screen was not designed to manage septage.

#### CONTROLS


QTY	UNIT	DESCRIPTION
1	EA	<b>Main Control Panel: 1 - LF</b> Power: 480V/3ph/60hz Panel Rating: NEMA 4X PLC/Relay Based: Relay Screen Instrumentation: Dual Mechanical Float Local Pushbutton Station(s): Three Button (E-Stop/Run/Jog Rev)

Notes: Pre-engineered controls package included. Changes to scope will have cost impacts.


#### TECH/FREIGHT

QTY	UNIT	DESCRIPTION
1	LOT	<b>On-Site Technical Assistance</b> Number of Trips: 1 Trip(s) Days On-Site per Trip: 1 8-hour man-day(s)
1	LOT	<b>Freight</b> FOB Factory, Full Freight Allowed








SECTION A-A  
SCALE 1:8



(\*z) ~ SELECT  
"DOWN STREAM" NOT SHOWN  
COMPACTOR  
WASH WATER  
CONNECTION



VERIFICATION BLOCK	
<b>WASHER COMPACTOR SELECTIONS</b>	<b>FLEXRAKE SELECTIONS</b>
Please Circle One:	Please Circle One:
WATER SUPPLY CONNECTION: (*z) = UPSTREAM or DOWNSTREAM	UNIT WIDTH: (*a) = 12" 18" 24"
MOTOR LOCATION: (*y) = RH or LH	MOTOR LOCATION: (*b) = RH or LH
DEBRIS BIN HEIGHT: _____	CHANNEL HEIGHT: (*c) = 2'-0" 2'-6" 3'-0" 3'-6" 4'-0" 4'-6" 5'-0" 5'-6" 6'-0"
INDOOR OR OUTDOOR _____	CHANNEL DEPTH CLEARANCE: MINIMUM NEEDED AT 3FT DEEP. (*d) = ADD 3.5" FOR EVERY 6" INCREASE OF DEPTH.
FLOW: PEAK _____ AVERAGE _____	SUPPLY WATER CONNETION: (*e) = RH or LH
WATER LEVEL: PEAK _____ AVERAGE _____	CLEAR BAR OPENING: (*f) = 1/4" 1/2" 3/4" 1"

-TEMPLATE-			
<b>CONCEPTUAL</b> THIS PROPOSAL DRAWING IS BASED UPON THE INFORMATION AVAILABLE AT THE TIME AND MAY BE IMPACTED BY FUTURE SPECIFICATION, SCOPE, AND OTHER REQUIREMENTS. PLEASE BE ADVISED THAT DUPERON CORPORATION RETAINS THE RIGHT TO REFUSE, WITHDRAW, OR NEGOTIATE THIS PROPOSAL AT ANY TIME PRIOR TO SIGNING MATERIAL CONTRACT		<b>PROPRIETARY</b> THIS MATERIAL IS THE EXCLUSIVE PROPERTY OF DUPERON CORPORATION AND MUST BE RETURNED TO DUPERON IMMEDIATELY UPON REQUEST. THIS MATERIAL AND THE INFORMATION ILLUSTRATED OR CONTAINED HEREIN MAY NOT BE REPRODUCED, COPIED, USED OR TRANSMITTED IN WHOLE OR IN PART IN ANY WAY WITHOUT THE PRIOR WRITTEN CONSENT OF DUPERON CORPORATION - SAGINAW, MI, USA	
DIMENSIONING & TOLERANCING IN ACCORDANCE WITH ANSI Y14.5M-1982 TOLERANCES - UNLESS OTHERWISE SPECIFIED .X = +0.13 .XX = +0.08 .XXX = +0.009 .XXXX = +0.0009 ANGULAR = ±0.5°		 Soginow, Michigan 48601 TF 800.383.8479	
DRAWN: WED CHECKED: CA APPROVED: - APPROVED: -	DATE: 04/03/19 DATE: ?/?/19 DATE: - DATE: -	SHEET TITLE <b>DUPERON CORPORATION</b> <b>LOW FLOW SYSTEM LAYOUT</b> PART NAME	
<b>FLEXRAKE &amp; LFWC SELECTIONS</b>		SIZE: D SCALE: 1:16	FSCM NO.: - DWG. NO.: - REV: - SHEET 1 OF 1

SHOWN WITH STANDARD (2)-PIECE "POSITIONABLE" DISCHARGE CHUTES.  
OTHER CHUTE CONFIGURATIONS AND LENGTHS AVAILABLE.  
CONSULTE DUPERON PRODUCT ENGINEERING.

# **Influent Flow Meter**

# LaserFlow<sup>®</sup> Ex

## Intrinsically Safe, Non-Contact Subsurface Velocity Sensor

The LaserFlow<sup>®</sup> Ex velocity sensor remotely measures flow in open channels with non-contact Laser Doppler Velocity technology and non-contact Ultrasonic Level technology. The sensor uses these advanced methods to measure velocity with a laser beam at single or multiple points below the surface of the wastewater stream. The sensor can be installed in hazardous areas defined as Class I, Div 1 or Zone 0.

*The only non-contact flow measurement device to read below the surface.*

The sensor uses an ultrasonic level sensor to measure the level and determines a sub-surface point to measure velocity. The sensor then focuses its laser beam at this point and measures the velocity from the frequency shift (doppler shift) of the returned light.


The LaserFlow Ex is ideal for a broad range of wastewater monitoring applications. With Teledyne ISCO's TIENet™ Barrier, it is compatible with both the Teledyne ISCO Signature<sup>®</sup> Flowmeter and the 2160 LaserFlow Module, depending on the type of installation.

During submerged conditions, flow measurement continues without interruption with optional continuous wave Doppler Ultrasonic Area Velocity technology.

With its specially designed mounting bracket in place, the LaserFlow Ex can be deployed and removed from street level. This avoids the risk and expense of confined space entry. A variety of communication options enable programming and data retrieval from a remote location. Information about data quality can be recorded and transmitted with the flow data.

Additionally, built-in diagnostic tools simplify installation, maintenance, and advanced communication options reduce site visits.

*The LaserFlow device can be programmed to take velocity measurements at single or multiple points below the water's surface.*



## LaserFlow<sup>®</sup>

### Applications:

- Hazardous Area Installations
- Flow measurement for CSO, SSO, I&I, SSEs, CMOM, and other sewer monitoring programs
- Wastewater treatment plant influent, process, and effluent flow measurement
- Industrial process and discharge flow measurement
- Shallow flow measurement in varying pipe sizes

### Standard Features:

- Intrinsically Safe Class I, Div 1, Zone 0
- Non-contact velocity and level measurement
- Single or multiple point measurement below the liquid surface
- Rugged, submersible enclosure with IP68 ingress protection
- Zero deadband from measurement point in non-contact level and velocity measurements
- Quality readings without manual profiling

## LaserFlow® Ex Sensor

Size (H x W x D):	18.0 x 9.5 x 23.5 in (45.7 x 24.1 x 59.7 cm)
Weight :	24.8 lbs (11.25 kg)
Materials:	Conductive Carbon Filled ABS, SST, Conductive Kynar® <sup>a</sup> , Anodized Aluminum, UV Rated PVC
Cable Lengths:	32.8 or 75.5 ft (10 or 23 m) <sup>b</sup>
Enclosure:	IP68
Certifications:	Class I, Division 1, Groups C-D, T4 Exia Class I, Zone 0, AEx ia op is IIB T4 Ga Ex II 1 G Ex ia op is IIB T4 Ga IECEx ia op is IIB T4 Ga
Laser Class:	Class 3R
Temperature Range:	Operating: 14 to 140 °F (-10 to 60 °C) Storage: -40 to 140 °F (-40 to 60 °C)
Power Required:	Input voltage: 8 to 26 VDC 16 VDC Nominal
Flow Accuracy:	±4% of reading <sup>c</sup>
Communication Protocol:	TIENet™

## Velocity

Technology:	Non-Contact, Subsurface Laser Doppler Velocity (patented)
Measurement Range:	0 to 15 ft/s (0 to 4.6 m/s)
Maximum distance from liquid surface to bottom of sensor:	10 ft (3 m)
Minimum depth:	0.5 in (1.27 cm) <sup>c</sup>
Accuracy:	±0.5% of reading 0.1 ft/s (±0.03 m/s)
Minimum Velocity:	0.5 ft/s (0.15 m/s)

## Level

Technology:	Non-Contact Ultrasonic
Measurement Range:	0 to 10 ft (0 to 3 m) from measurement point
Accuracy @ 72 °F (22 °C)	0.02 ft (±0.006 m) at <1 ft level change 0.04 ft (±0.012 m) at <1 ft level change
Temperature Coefficient within compensated range:	± 0.0002 x D (m) per degree C ± 0.00011 x D (ft) per degree F (D = Distance from transducer to liquid surface)
Beam Angle:	10° (5° from center line)
Ultrasonic Signal:	50 KHz
Deadband:	Zero deadband from bottom of LaserFlow sensor <sup>d</sup>

## Options and Accessories

- Redundant measurement with simultaneous Ultrasonic Level Sensing
- Permanent mounting hardware
- Sensor retrieval arm enables installation/removal without confined space entry
- Remote ultrasonic level sensor options for drop manhole and outfall applications

## Optional Surcharge Measurement:

### TIENet™ 350 Ex Area Velocity Sensor

Probe Size (H x W x L):	0.75 x 1.3 x 6.0 in (19 x 33 x 152 mm)
Materials:	Sensor: Epoxy, chlorinated CPVC, SST Cable: UV-Rated PVC
Certifications:	CE EN61326 <i>(Pending)</i> Class I, Division 1, Groups C-D, T4 Exia Class I, Zone 0, AEx ia IIB T4 Ga Ex II 1 G Ex ia IIB T4 Ga Ex ia IIB T4 Ga IECEx
Temperature Range:	32 to 158 °F (0 to 70 °C)

## Velocity

Technology:	Submerged Continuous Wave Doppler
Ultrasonic:	Measurement
Range:	-5 to 20 ft/s (-1.5 to 6.1 m/s)
Velocity Measurement:	Bidirectional
Accuracy:	±0.1 ft/s (±0.03 m/s) from -5 to 5 ft/s ±2% of reading from 5 to 20 ft/s, Uniform velocity profile
Minimum Depth:	0.08 ft (25 mm)
Frequency:	500 kHz

## Level

Technology:	Submerged Differential Linear Pressure Transducer
Measurement Range:	0.033 to 10 ft (0.01 to 3.05 m)
Accuracy:	± 0.10% of full scale
Maximum Depth:	34 ft (10.5 m)
Stability:	±0.023 ft/yr (±0.007 m/yr)

TIENet™ Barrier device provides safe electrical connections that allow the sensor to be installed in Intrinsically Safe areas.



IP66 enclosure for TIENet™ Barrier device.



<sup>a</sup> Kynar® is a registered trademark of Arkema, Inc.

<sup>b</sup> Custom cable lengths also available.

<sup>c</sup> Under normal flow conditions.

<sup>d</sup> Deadband for remote TIENet™ 310 ultrasonic level sensor varies, depending on the type of mounting hardware.

## Teledyne ISCO

P.O. Box 82531, Lincoln, Nebraska, 68501 USA  
Toll-free: (800) 228-4373 • Phone: (402) 464-0231 • Fax: (402) 465-3091



teledyneisco.com




Teledyne ISCO is continually improving its products and reserves the right to change product specifications, replacement parts, schematics, and instructions without notice.




### 360 LaserFlow Velocity Sensor and Wall Mounting Hardware



<b>LaserFlow SENSOR SPECIFICATIONS</b>	
<b>WEIGHT</b>	
MOUNT	11.5 LBS [5.2 KG]
LaserFlow SENSOR 10M	19.2 LBS [8.7 KG]
LaserFlow SNSR + AREA VELOCITY	20 LBS [9 KG]
<b>ENCLOSURE MATERIAL</b>	
HOUSING LaserFlow	CONDUCTIVE CARBON FILLED ABS
HOUSING ULTRASONIC	ANNODIZED ALUMINUM 6061
ULTRASONIC SENSOR	Kynar 340 RESIN PVDF GRADE
MOUNTING HARDWARE	STAINLESS STEEL
ALL OTHER EXTERIOR METAL PARTS	STAINLESS STEEL
<b>ELECTRICAL</b>	
POWER SUPPLY	TIENet BUS POWERED 8-26 VDC
<b>ELECTRICAL CONNECTIONS</b>	
TIENet DEVICE	SREW TERMINAL CONNECTION OR TIENet PLUG
LASER CLASS	CLASS 3R



### 360 LaserFlow Velocity Sensor and Temporary Mounting Hardware



NOTES:  
 1. SECONDARY DIMENSIONS IN BRACKETS ARE IN CENTIMETERS (CM),  
 UNLESS OTHERWISE SPECIFIED.

AREA VELOCITY  
 SENSOR ASSEMBLY  
 (OPTIONAL)

LaserFlow SENSOR SPECIFICATIONS	
<b>WEIGHT</b>	
CARGO BAR 48"-55" [122-140]	6.0 LBS [2.7 KG]
CARGO BAR 54"-66" [137-168]	6.5 LBS [2.9 KG]
CARGO BAR 63"-84" [160-213]	7.4 LBS [3.4 KG]
CARGO BAR 83"-114" [211-290] (SHOWN)	9.0 LBS [4.1 KG]
MOUNT	11.7 LBS [5.3 KG]
LaserFlow SENSOR 10M	19.2 LBS [8.7 KG]
LaserFlow SNSR + AREA VELOCITY	20 LBS [9 KG]
<b>FORCES</b>	
TOTAL FORCE	350 LBS [158.8 KG]
MAX LOAD	45 LBS [20.4 KG]
<b>ENCLOSURE MATERIAL</b>	
CARGO BAR	ALUMINUM
HANDLE & HYDRAULIC HOUSING	NYLON
FOOT	RUBBER
HOUSING LaserFlow	CONDUCTIVE CARBON FILLED ABS
HOUSING ULTRASONIC	ANNOIDIZED ALUMINUM 6061
ULTRASONIC SENSOR	Kynar 340 RESIN PVDF GRADE
MOUNTING HARDWARE	STAINLESS STEEL
ALL OTHER EXTERIOR METAL PARTS	STAINLESS STEEL

# **Sequential Batch Reactor (SBR) Design Calculations**

**DESIGN**

Stamp, NY Sanitaire #a29193-18

Max Month*	MGD	0.510	
Max 4.0hr Cycle Flow	MGD	0.765	
Max 3.0hr Cycle Flow	MGD	1.020	
		mg/l	lb/day
BOD <sub>5</sub> (20°C)		300	1276
Suspended Solids		250	1063
TKN(Assume 1.5 (NH <sub>3</sub> -N) = TKN)		60	255
NH <sub>3</sub> -N		40	170
Total Phosphorus		4	17
Max Wastewater Temperature	°C	20	
Min Wastewater Temperature	°C	6	
Ambient Air Temperature	°F	20 - 90	
Site Elevation	ft	500	

\* - Maximum 30 day period mass flow

**Table B: ICEAS® EFFLUENT QUALITY (MONTHLY AVERAGE)**

BOD <sub>5</sub> (20°C)	mg/l	10.0
Suspended Solids	mg/l	10.0
NH <sub>3</sub> -N	mg/l	1.2
Total Phosphorus	mg/l	0.8

\*Requires chemical precipitation

**Table C: ICEAS PROCESS DESIGN CRITERIA**

Operating Basins		3
Operating Top Water Level	ft	15.00
F / M	BOD <sub>5</sub> /DAY/MLSS	0.039
SVI (after 30 minutes settling)	ml/g	150
MLSS at Bottom Water Level	mg/l	5,080
Waste Sludge Produced (Approx.)	lb/day	969
Volume of Sludge Produced (Approx., 0.85% solids)	GPD	13,700
Normal Decant Rate	GPM	708
Peak Decant Rate	GPM	944
Hydraulic Retention Time	Days	1.62
Sludge Age	Days	32.0
Alkalinity	mg/l	295
Chemical Dosage (as Alum)	mg/l	42

***Bold, italicized text indicate assumptions made by Sanitaire***

**Cycle Timing**

		Max Month*	
		Normal	Min
Air-On	min	120	90
Settle	min	60	45
Decant	min	60	45
<b>Total</b>	<b>min</b>	<b>240</b>	<b>180</b>

**Table D: KEY ICEAS DESIGN DETAILS**



Top Water Level	ft	15.00
Basin Width (Inside)	ft	30.0
Basin Length (Inside)	ft	86.0
Bottom Water Level	ft	13.33
No. of Sludge Holding Tanks		3
SHT Top Water Level	ft	15.0
SHT Width	ft	25.0
SHT Length	ft	30.0
Sludge Storage Time	days	10

**ICEAS EQUIPMENT(Base Design)**

				Motor HP No. Req.
Decanter Mechanism	7.5 ' Weir length			3
Decanter Drive Unit			1/4	3
ICEAS Blower	440 SCFM	7.3 PSIG	30	3
ICEAS Fine Bubble Aeration System	280 Disc Diffusers/Basin			3
Air Control Valve	6 "			3
Waste Sludge Pump	110 GPM		2.4	3
ICEAS Controls				1
SHT Blower	320 SCFM	7.5 PSIG	25	4
SHT Aeration System	225 Disc Diffusers/Basin			3

**ICEAS POWER REQUIREMENTS**

	Max Month	<b>(At Average Aeration Depth)</b>			Kwh/Day
Decant Drive Unit	0.2 BHP	3 run	@	6 Hrs/day	2.7
ICEAS Air Blowers	22.6 BHP	1 run*	@	24 Hrs/day	404.6
ICEAS Air Blowers	22.6 BHP	1 run**	@	12 Hrs/day	202.3
Waste Sludge Pump	1.9 BHP	3 run	@	0.7 Hrs/day	3.0
				KWH/DAY	612.6
			AVERAGE	KWH/HR	25.53
* Shared ICEAS Blowers					
** Dedicated ICEAS Blowers					
SHT Blower	19.3 BHP	3 run	@	18 Hrs/day	775.60
				KWH/DAY	1,388.20
			AVERAGE	KWH/HR	57.84



**PRELIMINARY - THIS DRAWING IS NOT INTENDED FOR CONTRACT DOCUMENTS, SUBMITTALS, OR CONSTRUCTION**



CUST. NO.

DWG. NO.

THIS DRAWING IS THE PROPERTY OF XYLEM AND IS SUBMITTED IN CONFIDENCE. IT IS NOT TO BE DISCLOSED, USED OR DUPLICATED WITHOUT PERMISSION OF XYLEM.

Stamp, NY  
PRELIMINARY LAYOUT  
ICEAS System

DRAWN BY  
TDB

CHKD BY

APPVD BY

DATE  
4/30/20

DATE

DATE

JOB

a29193-18

SHEET

**SANITAIRE ICEAS Detailed Design Calculations**  
**BOD Removal and Nitrification Process**

**SANITAIRE Project #a29193-18**  
**Stamp, NY**

**Design Parameters**

**A. Flow**

Max Month 510,000 GPD  
 Max 4.0hr Cycle Flow 765,000 GPD  
 Max 3.0hr Cycle Flow 1,020,000 GPD

**B. Treatment**

	Influent Quality	Effluent Requirement
BOD <sub>5</sub> (20°C), mg/l	300	10
Suspended Solids, mg/l	250	10
TKN, mg/l	60	
NH <sub>3</sub> -N, mg/l		1
TN, mg/l		
Phosphorus	4	0.8

**C. Environment**

Alkalinity (Minimum Requirement) 300 mg/l  
 Max Wastewater Temperature 20 °C  
 Min Wastewater Temperature 6 °C  
 Ambient Air Temperature 20 - 90 °F  
 Site Elevation 500 ft

**D. ICEAS Process Design Criteria**

F / M 0.047 BOD<sub>5</sub> / MLSS / day  
 SVI (after 30 minutes settling) 150 ml/g  
 Number of ICEAS Basins 3  
 Top Water Level 15 ft

**E. Cycle Timing**

		Normal	Storm
Air-On	min	120	90
Air-Off	min		
Settle	min	60	45
Decant	min	60	45
Total	hrs	4	3

## F. Detailed Calculations

### Mass of BOD

$$\text{BODL} = \frac{Q \times \text{BODin} \times 8.34}{1,000,000} = \frac{170,000 \times 300 \times 8.34}{1,000,000} = \mathbf{425 \text{ lb/day/basin}}$$

where: BODL = BOD Load (lb/day/basin)  
 Q = Average Dry Weather Flow per basin (gal/day)  
 BODin = Influent BOD concentration (mg/l)  
 1,000,000 = Conversion (l/mg)  
 8.34 = Conversion (lb/gal)

### Mass of Biomass

$$\text{BMOB} = \frac{\text{BOD}_L}{F / M} = \frac{425}{0.0395} = \mathbf{10,778 \text{ lb/basin}}$$

where: BMOB = Mass of Biochemicalmass (lb/day/basin)  
 F / M = Food to Microorganism ratio (day<sup>-1</sup>)

### Volume of Biomass

$$\text{Vbio} = \text{BMOB} \times \text{SVI} = 10,778 \times 2.4 = \mathbf{25,867 \text{ ft}^3/\text{basin}}$$

where: Vbio = Volume of Biochemicalmass (ft<sup>3</sup>/basin)  
 SVI = Sludge Volume Index (ft<sup>3</sup>/lb)



## Maximum Volume Above Bottom Water Level

### Peak Dry Weather Flow:

$$V_{bwld} = \frac{PDWF \times (NCT - NDT)}{24 \times 7.48} = \frac{255,000 \times (4.0 - 1.00)}{24 \times 7.48} = \mathbf{4,261 \text{ ft}^3/\text{basin}}$$

where:  $V_{bwld}$  = Maximum Volume Above BWL at Peak Dry Weather Flow ( $\text{ft}^3/\text{basin}$ )

PDWF = Peak Dry Weather Flow (gal/day)

NCT = Normal Cycle Time (hr/cycle)

NDT = Decant Time (hr/cycle)

7.48 = Conversion ( $\text{gal}/\text{ft}^3$ )

24 = Conversion (hours/day)

### Peak Wet Weather Flow:

$$V_{bwls} = \frac{PWWF \times (SCT - SDT)}{24 \times 7.48} = \frac{340,000 \times (3.0 - 0.75)}{24 \times 7.48} = \mathbf{4,261 \text{ ft}^3/\text{basin}}$$

where:  $V_{bwls}$  = Maximum Volume Above BWL at Peak Wet Weather (Storm) Flow ( $\text{ft}^3/\text{basin}$ )

PWWF = Peak Wet Weather Flow (gal/day)

SCT = Storm Cycle Time (hr/cycle)

SDT = Storm Decant Time (hr/cycle)

MVAB (Maximum Volume Above Bottom Water Level) is larger of Peak Dry Weather and Peak Wet Weather Calculation

$$\mathbf{MVAB = 4,261 \text{ ft}^3/\text{basin}}$$

## Decant Rates

### Peak Dry Weather Flow:

$$PDR = \frac{MVAB \times 7.48}{NDT} + \frac{PDWF}{1,440} = \frac{4,261 \times 7.48}{60.0} + \frac{255,000}{1,440} = \mathbf{708 \text{ gal}/\text{min}}$$

where: PDR = Normal Decant Rate (gal/min)

NDT = Normal Decant Time (min/cycle)

1440 = Conversion (min/day)

### Peak Wet Weather Flow:

$$PWR = \frac{MVAB \times 7.48}{SDT} + \frac{PWWF}{1,440} = \frac{4,261 \times 7.48}{45.0} + \frac{340,000}{1,440} = \mathbf{944 \text{ gal}/\text{min}}$$

where: PWR = Peak Decant Rate (gal/min)

SDT = Storm Decant Time (min/cycle)

## Decanter Sizing

### Peak Dry Weather Flow:

$$DL_a = \frac{PDR}{\text{Weir Loading Rate} \times 7.48} = \frac{708}{20 \times 7.48} = \mathbf{4.73 \text{ ft}}$$

where: DL<sub>a</sub> = Decanter Length for Average Dry Weather Flow (ft)  
 20 = Weir Loading Rate (ft<sup>3</sup>/min/ft of decanter weir)

### Peak Wet Weather Flow:

$$DL_p = \frac{PWR}{\text{Weir Loading Rate} \times 7.48} = \frac{944}{25 \times 7.48} = \mathbf{5.05 \text{ ft}}$$

where: DL<sub>p</sub> = Decanter Length for Peak Wet Weather (Storm) Flow (ft)  
 25 = Weir Loading Rate (ft<sup>3</sup>/min/ft of decanter weir)

$$\text{Design Decanter Length} = \mathbf{7.5 \text{ ft}}$$

## Basin Working Volume

$$BWV = MVAB + V_{bio} = 4,261 + 25,867 = \mathbf{30,128 \text{ ft}^3/\text{basin}}$$

where: BWV = Basin Working Volume (ft<sup>3</sup>/basin)  
 V<sub>c</sub> = Volume of chemical sludge due to Phosphorus removal (ft<sup>3</sup>/basin)  
 (Please refer to phosphorus removal calculation.)

## Basin Area

$$BA = \frac{BWV}{TWL - BZ} = \frac{30,128}{15.0 - 3.2} = \mathbf{2,550 \text{ ft}^2/\text{basin}}$$

where: BA = Basin Area (ft<sup>2</sup>)  
 TWL = Top Water Level (ft)  
 BZ = Buffer Zone (ft) (Safety Factor)

## Sludge Depth

$$SD = \frac{V_{bio}}{BA} = \frac{25,867}{2,550} = \mathbf{10.14 \text{ ft}}$$

where: SD = Sludge Depth (ft)

**Decanter Draw Down**

$$DD = \frac{MVAB}{BA} = \frac{4,261}{2,550} = \mathbf{1.67 \text{ ft}}$$

where: DD = Draw Down (ft)

**Bottom Water Level**

$$BWL = SD + BZ + Vd = 10.14 + 3.19 + 0.05 = \mathbf{13.33 \text{ ft}}$$

where: BWL = Bottom Water Level (ft)  
 Vd = Depth of Chemical Sludge for Phosphorus precipitation (ft)

**Top Water Level**

$$TWL = BWL + DD = 13.33 + 1.67 = \mathbf{15.00 \text{ ft}}$$

where: TWL = Top Water Level (ft)

**Hydraulic Retention Time**

$$HRT = \frac{BA \times MAFD \times 7.48}{QT}$$

where: HRT = Hydraulic Retention Time (days)  
 MAFD = Maximum Average Flow Depth (ft)  
 QT = Fill Rate at Average Dry Weather Flow (gal/day)

$$MAFD = \frac{Q \times [(NCT \times 60) - NDT]}{BA \times 1,440 \times 7.48} + BWL = \frac{170,000 \times [(4.0 \times 60) - 60.0]}{2,550 \times 1,440 \times 7.48} + 13.33 = \mathbf{14.44 \text{ ft}}$$

$$HRT = \frac{2,550 \times 14.44 \times 7.48}{170,000} = \mathbf{1.62 \text{ days}}$$



**MLSS Concentration at Bottom Water Level**

$$MLSS = \frac{M_{bio} \times 1,000,000}{BWL \times BA \times 62.42} = \frac{10,778 \times 1,000,000}{13.33 \times 2,550 \times 62.42} = \mathbf{5,080 \text{ mg/l}}$$

where: MLSS = Mixed Liquor Suspended Solids concentration at Bottom Water Level (mg/l)  
 62.42/1E+06 = Conversion (lb/mg x l/ft³)  
 CA = Area Increment due to chemical sludge (ft²/basin)

**Mass of Sludge Produced**

$$\Delta M = \left( \frac{Y \times (BOD_{in} - BOD_{out})}{1 + (B \times \theta^{(T-20)} \times SRT)} + Z_{io} + Z_{no} \right) \times \frac{Q \times 8.34}{1,000,000} + C_{sludge}$$

$$\Delta M = \left( \frac{0.6 \times (300 - 10.0)}{1 + (0.07 \times 1.02^{(6-20)} \times 32.0)} + 50.0 + 75.0 \right) \times \frac{1.7E+05 \times 8.34}{1,000,000} + 51 = \mathbf{323 \text{ lb/day/basin}}$$

(Lawrence-McCarty Equation as presented in WEF MOP/8 4th Edition, pg 11-11, Eqn. 11.7)

where:  $\Delta M$  = Mass of Sludge Produced (lb/day/basin)  
 Y = Volatile cell yield (VSS/BOD removed)  
 q = Arrhenius Temperature Correction Factor  
 B = Decay Rate (day<sup>-1</sup>)  
 BOD<sub>out</sub> = Anticipated Effluent BOD (mg/l)  
 SRT = Solids Retention Time (days)  
 Z<sub>io</sub> = Nonvolatile Influent suspended solids (mg/l)  
 Z<sub>no</sub> = Volatile Non-Biodegradable solids (mg/l)  
 T = Minimum Wastewater Temperature (°C)



**Volume of Sludge Produced**

$$V_{ws} = \frac{\Delta M}{SFws \times 8.34} = \frac{323}{0.0085 \times 8.34} = \mathbf{4,555 \text{ gal/day/basin}}$$

where: Vws = Volume of Waste Sludge (gal/day/basin)  
 SFws = Solids Fraction in Waste Sludge  
 8.34 = Density (lb/gal)

**Observed Yield Factor**

$$Y_{obs} = \frac{\Delta M}{BOD_L} = \frac{323}{425} = \mathbf{0.759 \frac{MLSS}{BOD}}$$

Observed Yield Factor (lb/day MLSS/lb/day BODremoved)

**Mean Cell Residence Time**

$$MCRT = \frac{M_{bio}}{\Delta M + ((Q - V_{ws}) \times TESS \times 8.34 / 1E+06)}$$

$$MCRT = \frac{10,778}{323 + ((170,000 - 4,555) \times 10.0 \times 8.34 / 1,000,000)} = \mathbf{32.0 \text{ days}}$$

where: MCRT = Mean Cell Residence Time (days)  
 TESS = Anticipated Effluent Total Suspended Solids (mg/l)  
 8.34E-06 = Conversion (lb/mg x l/gal)



## Sludge Age for Nitrification

Refer to Metcalf and Eddy, Edition IV pages 614 and 705

Constants and Temperature Corrections:

Coefficient	Base Value	Theta	Temperature Corrected	Symbol
Maximum Specific Growth Rate of Nitrifying bacteria, g VSS/g VSS.day	0.75	1.07	0.291	$\mu_{nm}(T)$
Half-Velocity constant for nitrifiers	0.74	1.053	0.359	$K_n(T)$
Nitrifier decay rate	0.08	1.04	0.046	$K_{dn}(T)$
Dissolved Oxygen, mg/l	2		2	DO
Half-Velocity Constant for Dissolved Oxygen, mg/l	0.5		0.5	$K_o$
Minimum Water Temperature, °C	6		6	T
Safety Factor	2.0		2.0	SF

Calculations:

$$\mu_n = \left( \mu_{nm}(T) \times \frac{TENH_3}{TENH_3 + K_n(T)} \times \frac{DO}{DO + K_o} \right) - K_{dn}(T)$$

$$\mu_n = \left( 0.291 \times \frac{1.0}{1.0 + 0.359} \times \frac{2.0}{2.0 + 0.5} \right) - 0.046 = \mathbf{0.125 \text{ days}^{-1}}$$

$$SRT_{min} = \frac{1}{\mu_n} = \frac{1}{0.125} = \mathbf{8.0 \text{ days}}$$

$$SRT_{aerobic} = SRT_{min} \times SF = 8.0 \times 2.0 = \mathbf{16.0 \text{ days}}$$

$$SRT_{overall} = \frac{SRT_{aerobic} \times 24}{TA} = \frac{16.0 \times 24}{12.0} = \mathbf{32.0 \text{ days}}$$

**Design sludge age adequate for nitrification.**

where:  $\mu_{nm}(T)$  = Maximum Temperature Corrected Nitrifier Growth Rate ( $\text{days}^{-1}$ )

$\mu_n$  = Specific Nitrifier Growth Rate at Temperature, DO, and Effluent  $NH_3$  (g/g-days)

$SRT_{min}$  = Minimum Sludge age required for Nitrification (days)

$SRT_{aerobic}$  = Design Aerobic Sludge Age (days)

SF = Safety Factor

$SRT_{overall}$  = Sludge Age accounting for entire ICEAS cycle (days)

TA = Aeration Time (hrs/day)

$TENH_3$  = Anticipated Effluent Ammonia (mg/l)

**Waste Sludge Pump Capacity**

$$WSP = \frac{Vws \times NCT}{24 \times SPT} = \frac{4,555 \times 4.0}{24 \times 6.90} = \mathbf{110 \text{ gal/min}}$$

where: WSP = Waste Sludge Pump Capacity(gal/min)  
 SPT = Sludge Pumping Time (min/cycle)

**Biological Phosphorus Removal**

$$TPb = TPi - TPe - [Yobs \times (BODin - BODout)] \times TPps \times VSS/TSS = 4.0 - 0.80 - [0.759 \times (300 - 10.0) \times 0.000 \times 0.622] = \mathbf{3.20 \text{ mg/l}}$$

where: TPb = Concentration of the Soluble Phosphorus to be removed (mg/l)  
 TPi = Concentration of the Total Phosphorus in the Influent (mg/l)  
 TPps = Percent of Total Phosphorus in VSS in WAS

**Chemical Dosing**

$$CD = MolR \times TPb \div Ion \times MWRatio$$

where: CD= Required Ferric Chloride dosing rate, mg/l  
 MolR= Mole Ratio (Actual Dose required vs. Stoichiometric Dose)  
 Ion= Fraction Metal Ion in Ferric Chloride  
 MWRatio= Ratio of Molecular Weights, Fe:P

Mole Ratio for Metal Salt Dosage Based on effluent Phosphorus concentration.  
 Mole ratio based on curves in Activated Sludge and Nutrient Removal, WEF OM-9, 3rd edition, 2018

$$CD = 2.51 \times 3.20 \div 0.348 \times 1.81 = \mathbf{42 \text{ mg/l}}$$

**Mass of Chemical Sludge**

$$Csludge = \frac{Q \times TPb \times 11.25 \times 8.34}{1,000,000} = \frac{170,000 \times 3.20 \times 11.25 \times 8.34}{1,000,000} = \mathbf{51 \text{ lb/day/basin}}$$

where: 11.25= Mass of Precipitate formed per Mass of P removed

**Volume of Chemical Sludge**

$$Vcs = Csludge \times SVI \times SA = 51 \times 2.4 \times 32.0 = \mathbf{3,936 \text{ ft}^3/\text{basin}}$$

where: Vcs = Volume of Chemical Sludge (ft<sup>3</sup>/basin)

*SANITAIRE ICEAS Aeration Design Calculations  
BOD Removal and Nitrification Process*

*SANITAIRE Project #a29193-18  
Stamp, NY*

**Carbonaceous Oxygen Demand**

$$AOR1 = A \times \frac{Q \times BOD_{in}}{1,000,000} \times 8.34 = 1.20 \times \frac{170,000 \times 300}{1,000,000} \times 8.34 = \mathbf{510 \text{ lb/day/basin}}$$

- where AOR1 = Actual Oxygen Required for BOD oxidation (lb/day/basin)
- A = O<sub>2</sub> / BOD
- Q = Average flow (gal/day/basin)
- BOD<sub>in</sub> = Influent BOD received (mg/l)
- 1,000,000 = Conversion (g x mg)
- 8.34 = Conversion (lb x gal)

**Nitrification Oxygen Demand**

$$AOR2 = TKN_{ox} \times 4.60 = 61.3 \times 4.60 = \mathbf{282 \text{ lb/day/basin}}$$

- where AOR2 = Actual Oxygen required for Ammonia Oxidation (lb/day/basin)
- TKN<sub>ox</sub> = Nitrogen available for oxidation (lb/day/basin)

Constants

Coefficient	Value	Symbol
VSS/TSS	0.6222	
Sludge N	0.1	N <sub>s</sub>
Effluent Dissolved Organic Nitrogen, mg/l	1	EDON
Expected Effluent Ammonium concentration	1	TENH <sub>3</sub>

$$TKN_{ox} = (TKN - EDON - TENH_3 - N_{assim} - N_{part}) \times Q \times 8.34 \div 1,000,000$$

$$TKN_{ox} = (60 - 1 - 1 - 14.17 - 0.62) \times 170,000 \times 8.34 \div 1,000,000 = \mathbf{61.3 \text{ lb/day/basin}}$$

where N<sub>assim</sub> = Nitrogen assimilated into biomass, (mg/l)

$$N_{assim} = BOD_{in} \times N_s \times Y_{obs} = 300 \times 0.1 \times 0.759 = \mathbf{14.17 \text{ mg/l}}$$

where Y<sub>obs</sub> = Observed Sludge Yield, (MLSS produced / BOD removed)

$$N_{part} = TESS \times N_s \times VSS/TSS = 10 \times 0.1 \times 0.62 = \mathbf{0.62 \text{ mg/l}}$$

where N<sub>part</sub> = Nitrogen bound to VSS portion of effluent TSS (mg/l)

TESS = Anticipated Effluent Total Suspended Solids (mg/l)

**Denitrification Oxygen Credit**

$$O_{2denit} = 2.9 \times NO_3-N_{denit} = 2.9 \times 42 = \mathbf{122 \text{ lb/day/basin}}$$

where  $O_{2denit}$  = Oxygen mass credit from denitrification (lb/day/basin)

$NO_3-N_{denit}$  = Mass of  $NO_3-N$  denitrified (lb/day/basin)

$$NO_3-N_{denit} = \mu_{DN} \times VSS/TSS \times BMOB \times ART = 0.00075 \times 0.62 \times 10,778 \times 8.31 = \mathbf{42 \text{ lb/day/basin}}$$

where

$\mu_{DN}$  = Denitrification rate at 6°C (NO<sub>3</sub>/MLVSS/hr)

BMOB = Basin biomass (lb/basin)

ART = Anoxic Retention Time, (hrs/day)

**Total Actual Oxygen Transfer**

$$AOR = AOR1 + AOR2 - O_{2denit} = 510 + 282 - 122 = \mathbf{671 \text{ lb/day/basin}}$$

where AOR = Total Actual Oxygen Required (lb/day/basin)

**Total Standard Oxygen Transfer**

$$SOR = \frac{AOR}{AOR / SOR} = \frac{671}{0.4820} = \mathbf{1,393 \text{ lb/day/basin}}$$

$$\frac{AOR}{SOR} = \frac{\alpha \times \theta^{(T_{site} - 20)} \times (\beta \times C^*_{sat_{20}} \times P_{site} / P_{std} \times C_{surf_T} / C_{surf_{20}} - D.O.)}{C^*_{sat_{20}}}$$

$$\frac{AOR}{SOR} = \frac{0.65 \times 1.024^{(20 - 20)} \times (0.95 \times 10.37 \times 14.46 / 14.70 \times 9.07 / 9.07 - 2.0)}{10.37} = \mathbf{0.4820}$$

where SOR = Standard Condition Oxygen Requirement (lb/day/basin)

$\alpha$  = Alpha factor

$\theta$  = Temperature coefficient

$T_{site}$  = Water temperature (°C)

$\beta$  = Beta factor

$P_{site}$  = Site Atmospheric Pressure

$P_{std}$  = Standard atmospheric pressure (psig)

$C^*_{sat_{20}}$  = Dissolved oxygen solubility at standard conditions (mg/l)

$C_{surf_T}$  = Dissolved oxygen solubility at site water temperature (mg/l)

$C_{surf_{20}}$  = Dissolved oxygen solubility at 20°C (mg/l)

D.O. = Residual dissolved oxygen concentration (mg/l)

## Aeration System Standard Oxygen Transfer Rate

$$\text{SOTR} = \frac{\text{SOR}}{\text{TA}} = \frac{1,393}{12} = \mathbf{116 \text{ lb/hr/basin}}$$

where SOTR = Standard oxygen transfer rate (lb/hr/basin)  
TA = Aeration Time, (hrs/day)

## Aeration Depth

Average Aeration Depth

$$\text{AADad} = \frac{Q \times [( \text{NCT} \times 60 ) - ( \text{NDT} + \text{NST} )]}{2 \times 1,440 \times 7.48 \times \text{BA}} + \text{BWL}$$

$$\text{AADad} = \frac{170,000 \times [( 4.0 \times 60 ) - ( 60 + 60 )]}{2 \times 1,440 \times 7.48 \times 2,550} + 13.33 = \mathbf{13.70 \text{ ft}}$$

where AADad = Average Aeration Depth at Average Dry Weather Flow (gpd)  
 Q = Average Dry Weather Flow (gpd/basin)  
 NCT = Normal Cycle Time (hr)  
 NDT = Normal Decant Time (min)  
 NST = Normal Settling Time (min)  
 BA = Basin Area (ft<sup>2</sup>)  
 1440 = Conversion (min/day)  
 2 = Calculate Aeration Depth at Middle of Normal Reaction Phase (NCT - NST - NDT)  
 7.48 = Conversion (gal/ft<sup>3</sup>)

## Maximum Aeration Depth

$$\text{MAD}_{pw} = \frac{\text{PWWF} \times [(\text{SCT} \times 60) - (\text{SDT} + \text{SST})]}{1,440 \times 7.48 \times \text{BA}} + \text{BWL}$$

$$\text{MAD}_{pw} = \frac{340,000 \times [(3.0 \times 60) - (45 + 45)]}{1,440 \times 7.48 \times 2,550} + 13.33 = \mathbf{14.44 \text{ ft}}$$

where  $\text{MAD}_{pw}$  = Maximum Aeration Depth at Peak Wet Weather Flow (gpd)

PWWF = Peak Wet Weather Flow (gpd/basin)

SCT = Storm Cycle Time (hr)

SDT = Storm Decant Time (min)

SST = Storm Settle time (min)

MAD = Maximum Aeration Depth (ft)

MAD is larger of MAD<sub>ad</sub> and MAD<sub>pw</sub>

$$\text{MAD} = \mathbf{14.44 \text{ ft}}$$

## Air Flow Requirement

$$\text{Process Air} = \frac{\text{SOTR} \times 10,000}{\rho \times \text{SOTE} \times \text{Opw} \times 60} = \frac{116 \times 10,000}{0.075 \times 25.59 \times 23.2 \times 60} = \mathbf{434 \text{ scfm}}$$

where Process Air = Process air flow requirement (scfm)

$\rho$  = Air density (0.075 lb/day/ft<sup>3</sup>)

SOTE = Standard Oxygen Transfer Efficiency @ Submergence of 12.70 ft

Opw = Fraction of Oxygen in air by Weight

10,000 = Conversion (100% \* 100%)

60 = Conversion (min/hr)

$$\text{Mixing Air} = \text{MI} \times \text{BA} = 0.13 \times 2,550 = \mathbf{319 \text{ scfm}}$$

where Mixing Air = Mixing air flow requirement (scfm)

MI = recommended air flow per unit area of basin (scfm/ft<sup>2</sup>)

## Blower Unit Capacity

Blower unit capacity (BUC) is the larger of the process air requirement and the mixing air requirement.

Process Air            434 scfm

Mixing Air            319 scfm

Use 1 blower per tank

$$\text{BUC} = 440 \text{ scfm}$$

## Blower Pressure

$$\text{psig} = \text{MAD} \times 0.432 + H_L = 14.44 \times 0.432 + 1.00 = 7.3 \text{ psig}$$

where    psig = blower pressure (rounded to next psig)

0.432 = water density (psi/ft)

$H_L$  = Cumulative piping and diffuser headloss (psig)

## Average Blower Power

Blower power based on vendor curves, BUC, and Average Aeration Depth (12.70 ft)


$$\text{Power}_{\text{avg}} = 22.6 \text{ bhp}$$



Project Name: **STAMP**  
 Sanitaire Number: **A29193-17**



**ICEAS 6-Basin NIT Normal Cycle 240 mins (4 hours)**



Notes:


Each basin fills continuously over entire cycle. Basins #1 and #2, #3 and #4, #5 and #6 share blowers.

"Air On" periods in the react phase are programmable from 0 to 40 minutes.

Sludge wasting occurs during the decant phase, pump run time is programmable.

During the storm cycle, the time segments are reduced by 25% to accommodate additional flow.

**Project Name: STAMP**  
**Sanitaire Number: A29193-17**  
**ICEAS 6-Basin NIT High Flow Mode 180 mins (3 hours)**



Notes:  
 Each basin fills continuously over entire cycle. Basins #1 and #2, #3 and #4, #5 and #6 share blowers.  
 "Air On" periods in the react phase are programmable from 0 to 30 minutes.  
 Sludge wasting occurs during the decant phase, pump run time is programmable.  
 During the storm cycle, the time segments are reduced by 25% to accommodate additional flow.

# **Sludge Holding Tank (SHT) Design Calculations**

**SANITAIRE Detailed Design Calculations**

**Sludge Holding Tank**

**SANITAIRE Project #A29193-20  
STAMP, NY**

**Design Parameters**

**A. Sludge Characteristics**

Q <sub>i</sub> Daily Flow to Digester		27 332	GPD
TSS <sub>i</sub> TSS Concentration to Digester		0.85%	w/w
TSS <sub>E</sub> TSS Concentration in Digester	(after decanting)	1.60%	w/w
VSS <sub>i</sub> VSS Concentration to Digester		62.2%	w/w

**B. Site Characteristics**

T <sub>max</sub> Max Wastewater Temperature		30	°C
T <sub>min</sub> Min Wastewater Temperature		6	°C
T <sub>a</sub> Ambient Air Temperature		20 - 90	°F
E Site Elevation		310	ft
SRT <sub>2</sub> Aerobic SRT of Upstream Secondary Process		16	days

**C. Aerobic Digester Basin Dimensions**


Process	Vorelodos Energy Saving with Decanter		
Baffle Configuration	No		
Digester Type	Parallel		
N Number of Digesters	Rectangular		
N Number of Digesters	6		
V <sub>TWL</sub> Volume/Digester at TWL	10 800	ft <sup>3</sup>	
L Digester Length	30	ft <sup>3</sup>	
W Digester Width	24	ft	
A <sub>d</sub> Digester Area	720	ft <sup>2</sup> /AD	
TWL Digester Depth at TWL	15.00	ft	

**D. Cycle Times**

C <sub>A</sub> React - anaerobic/anoxic (air off)			h
C <sub>O</sub> React - aerobic (air on)	21.0		h
C <sub>S</sub> Settle	2.8		h
C <sub>D</sub> Decant	0.3		h
C <sub>T</sub> Total	24.0		h
C <sub>W</sub> Desludge	60.0	min	

Operation (Iterative Solution - values confirmed below)

SRT <sub>T</sub> Digester Total Solids Retention Time	37.1	days
HRT Digester Hydraulic Retention Time (HRT)	17.2	days
VSS <sub>d</sub> Predicted VSS Destruction in digester (relative to VSS concentration in WAS from 2ndary process)	20.3%	VSSd



**E. Confirm Aerobic Digester VSS Destruction, VSS<sub>d</sub> (based on Digester Total SRT listed above)**

	Upstream		
	2ndary	Aerobic	
	Process	Digester	Total

SRT <sub>A</sub> Aerobic SRT	16.0	32.4	48.4 days
Degree-Days at T <sub>min</sub>	96	195	291 degree-days
VSS Destruction (relative to 2ndary Process Influent)	15%	17%	32%

Where: SRT<sub>A</sub> for Aerobic Digester = 37.1 days total SRT x 21.0 hr/d air / 24 hr/d = 32.4 days

VSS destruction in upstream 2ndary process and digester based on Fig 13-35 in Metcalf & Eddy, 5th edition and degree-days in each part of process  
 To understand this, compare Fig 13-35 in Metcalf & Eddy, 5<sup>th</sup> edition with Equation 8-20 M+E 5<sup>th</sup> edition or 8-15 M+E 4<sup>th</sup> edition.  
 Equation 8-20 calculates the VSS sludge production related to SRT for a WWTP. Aerobic digestion SRT is just an extension of the upstream 2ndary process, but in another tank, so the shape of the Eq 8-20 secondary treatment VSS<sub>d</sub> curve is the same as Fig 13-35 aerobic digester VSS<sub>d</sub> curve.  
 Figure 13-35 was based on data from non-nitrifying plants with relatively low aerobic SRT values, so to accurately predict the VSS destruction in an aerobic digester, the VSS destruction in the upstream 2ndary process must also be taken into account.

$$VSS_d = 1 - [(1 - VSST) / (1 - VSS_2)] = 1 - (1 - 32\%) / (1 - 15\%) = 20.3\%$$

Where: VSS<sub>T</sub> = Total VSS destruction in upstream 2ndary process and aerobic digester combined, relative to VSS concentration in 2ndary process influent  
 VSS<sub>T</sub> = VSS destruction in aerobic digester, relative to VSS concentration in 2ndary process influent

**F. Calculate Volume of Supernate and Digester Sludge, Digester BWL, and confirm assumed SRT at BWL**

Calculate mass of digested sludge using VSS destruction listed above

	Biosolids to Digester	Biosolids from Digester	
Inerts	733	733	lbTSS/d
Mass <sub>VSS</sub>	1205	960	lbTSS/d
Mass <sub>TSS</sub>	1938	1693	lbTSS/d

Where: Digested Mass<sub>VSS</sub> = Q<sub>i</sub> x 8.34 x TSS<sub>i</sub> / 1,000,000 x VSS<sub>i</sub> x (1 - VSS<sub>d</sub>) = 27 332 x 8.34 x 0.85% / 1,000,000 x 62.2% x (100% - 20.3%) = 960 lbTSS/d

Calculate volume of digested sludge using mass of digested sludge listed above

Q<sub>s</sub> Digested Sludge Flow = Mass<sub>TSS</sub> / 8.34 / TSSE x 1,000,000 = 1 693 / 8.34 / 1.60% x 1,000,000 = 12 687 GPD

F Decant Frequency = Once Every 1 Days

Q<sub>d</sub> Daily Decant Flow = (Q<sub>i</sub> - Q<sub>s</sub>) \* F = (27 332 - 12 687) \* 1 = 14 645

BWL Digester Depth at BWL = [N x Ad x TWL - (QD/7.48)] / Ad / N = [6 x 720 x 15 - (14 645 / 7.48)] / 720 / 6 = 14.5 ft

Mass<sub>BWL</sub> Digester TSS Mass at BWL = [N x Ad x BWL x 7.48] / 1,000,000 x 8.34 x TSSE = (6 x 720 x 14.5 x 7.48) / 1,000,000 x 8.34 x 16 000 = 62 725 lb

Confirm SRT Assumed Above:

$$Digester\ Total\ SRT = Mass_{BWL} / 1,000,000 \times 8.34 \times TSSE = 37.0\ days$$

**G. Calculate Digester AOR, based on VSS Destruction Calculated Above**

Assume unit mass of O<sub>2</sub> required per unit mass of VSS destroyed as: 2.3 lbO<sub>2</sub>/lbVSS<sub>d</sub>

AOR<sub>D</sub> AOR per Digester = (Mass<sub>VSSin</sub> - Mass<sub>VSSout</sub>) x 2.3 lbO<sub>2</sub>/lbVSS<sub>d</sub> / N \* 24 / Co = (1 205 - 960) x 2.3 / 6 x 24 / 21.0 = 4.5 lbO<sub>2</sub>/h

**Sludge Holding Tank Design Proposal**  
 STAMP, NY Sanitaire #A29193-20

**Table A: SLUDGE CHARACTERISTICS AND SITE CONDITIONS**

Daily Flow to Digester		27 332 GPD
Daily Decant Flow		14 645 GPD
Daily Desludge Flow		12 687 GPD
TSS Concentration to Digester		0.85% w/w
TSS Concentration in Digester	(after decanting)	1.60% w/w
Max Wastewater Temperature		30 °C
Min Wastewater Temperature		6 °C
Ambient Air Temperature		20 - 90 °F
Site Elevation		310 ft

**Table B: DESIGN CRITERIA**

Process	Vorelodos Energy Saving with Decanter
Baffle Configuration	No Parallel
Digester Type	Rectangular
Digester Solids Retention Time (SRT)	37.1 days
Digester Hydraulic Retention Time (HRT)	17.2 days
Predicted VSS Destruction	20% VSSd

**Table C: DESIGN DETAILS**

Number of Digesters	6
Volume/Digester at TWL	10 800 ft <sup>3</sup>
Volume/Digester average	10 538 ft <sup>3</sup>
Digester Length	30.0 ft
Digester Width	24.0 ft
Digester Depth at TWL	15.00 ft
Digester Depth average	14.64 ft
Minimum Digester Depth with Mixer Operating	4.85 ft
Maximum Downstream Water Level	11.23 ft

## PROCESS EQUIPMENT

Fine Bubble Aeration Diffuser Quantity / Digester	32
Number of Aerated Zones / Digester	1
Blower Flowrate for Process / Digester	74 scfm
Blower Flowrate for Mixing 30scfm/kft <sup>3</sup> / Digester *	324 scfm
Blower Flowrate Proposed / Digester	74 scfm
Blowers (PD type) Quantity / Digester (Duty)	1
Blowers (PD type) Quantity Total (Duty / Standby)	6 / 1
Blowers (PD type) Motor Rating each	8 Hp
Mixer Quantity / Digester	1
Mixer Motor Rating each	3 Hp
Desludge Pump Quantity / Digester (Duty / Standby)	1 / 1
Desludge Pump Flowrate	235 GPM
Desludge Pump Motor Rating each	5.0 Hp
Decanter Quantity / Digester	1
Decanter Flowrate	162.7 GPM
Decanter Motor Rating each	0.25 Hp
OSCAR Controls and DO and ORP Instrumentation	

\* May require a waiver for States that require 10scfm/1000ft<sup>3</sup>

## AERATION/MIXING POWER REQUIREMENTS (TOTAL FOR ALL TRAINS)

Operating Power / Blower	5 Hp
Operating Power / Mixer	2.8 Hp
Operating Power / Decanter	0.3 Hp
Total Operating Power	745 kWh/d

# **SBR Aeration Blowers**



**POSITIVE DISPLACEMENT BLOWER**

Date: 10-08-2020

Page: 1

**PACKAGE RECOMMENDATIONS**

Customer: Alabama, NY

Prepared by: K. Ballew

**Design data:**

Operating mode: Gauge pressure	Flow medium: Air
Inlet pressure: 14.3 psia	Pressure differential: 8.4 psig
Inlet temperature: 100 °F	Discharge pressure: 22.7 psia
Air Humidity: 50%	Operation with FC (VFD): Yes

**Technical data:**

Package type: <b>Com-paK</b>	Maximum pressure differential: 8.7 psig
Package: <b>DB 166 C</b>	Blower speed (60 Hz): 4535 rpm
Blower: Omega 42P	% of blower's maximum speed: 94%
Drive motor: 30.0 hp	Inlet flexible connector: Piped- 4" Sleeve
Drive motor power: 460V / 3 / 60Hz	Discharge flexible connector: Piped- 4" Sleeve
Ventilation fan power: 115V / 1 / 60Hz	

**Performance data:**

	<b>Min Frequency</b>	<b>Design Point</b>	<b>Max Frequency</b>
Frequency	18 Hz	58.9 Hz	60 Hz
Speed	1361 rpm	4454 rpm	4535 rpm
Inlet flow Q1*:	108 cfm	491 cfm	501 cfm
Air flow Q1 (standard):	96 scfm	440 scfm	449 scfm
<small>standard conditions:14.7 psia, 68°F, 36% RH</small>			
Discharge temperature:	275 °F	228 °F	228 °F
Blower shaft power:	7.3 hp	24.6 hp	25.1 hp
Sound pressure level**:	72 dB(A)		
Sound power level**:	88 dB(A)		
Estimated weight:	1140 lb		
Dimensions (W x L x H)	44.0 x 46.0 x 51.0 inches		

\* Performance data to DIN ISO 1217- Annex C  
 \*\*Measured to DIN EN ISO 2151, figures ± 3 dB(A), with isolated pipework



Customer: Alabama, NY

Prepared by:

K. Ballew

**Equipment Scope:**

- Inlet silencer w/ filter (grade G4)
- Blower Block w/ Input Shaft Lip Seal
- Oil drains with ball valves
- V-Belt drive w/ automatic belt tensioner
- IP 55 TEFC Inverter rated drive motor (NPE)
- Discharge silencer
- Pressure relief valve
- Vibration isolators
- Sound enclosure with vent fan
- Flexible connectors on inlet and discharge
- Flap style check valve (plate)

**Standard instrumentation:**

- Discharge temperature gauge with switch
- Discharge pressure gauge
- Inlet filter differential pressure gauge

**Supplied**

- yes
- yes
- yes

**Optional accessories:**

- Unloaded Start valve
- Inlet filter differential pressure switch
- Discharge pressure switch
- Discharge pressure sensor (output 4-20mA)
- Enclosure safety temperature switch (thermostat)
- Enclosure heater, 115v (auxiliary heater)
- Outdoor designed sound enclosure

**Supplied**

- no
- no
- no
- no
- no
- no
- no


Comments/ Customer requirements:

**Notes:**

- a. Blower package requires blower controls.
- b. Motors, silencers, instrumentation and supplied accessories shown above are all factory mounted.

# OMEGA 42PLUS

PRESSURE PERFORMANCE  
14,7 PSIA and 68°F



# **SHT Aeration Blowers**



**POSITIVE DISPLACEMENT BLOWER**

Date: 10-08-2020

Page: 1

**PACKAGE RECOMMENDATIONS**

Customer: Alabama, NY

Prepared by: K. Ballew

**Design data:**

Operating mode: Gauge pressure	Flow medium: Air
Inlet pressure: 14.3 psia	Pressure differential: 8.5 psig
Inlet temperature: 100 °F	Discharge pressure: 22.8 psia
Air Humidity: 50%	Operation with FC (VFD): Yes

**Technical data:**

Package type: <b>Com-paK</b>	Maximum pressure differential: 10.1 psig
Package: <b>CB 131 C</b>	Blower speed (60 Hz): 4535 rpm
Blower: Omega 41P	% of blower's maximum speed: 91%
Drive motor: 25.0 hp	Inlet flexible connector: Piped- 3" Sleeve
Drive motor power: 460V / 3 / 60Hz	Discharge flexible connector: Piped- 3" Sleeve
Ventilation fan power: 115V / 1 / 60Hz	

<b>Performance data:</b>	<b>Min Frequency</b>	<b>Design Point</b>	<b>Max Frequency</b>
Frequency	18 Hz	59.1 Hz	60 Hz
Speed	1361 rpm	4471 rpm	4535 rpm
Inlet flow Q1*:	78 cfm	368 cfm	374 cfm
Air flow Q1 (standard):	70 scfm	330 scfm	335 scfm
<small>standard conditions:14.7 psia, 68°F, 36% RH</small>			
Discharge temperature:	287 °F	230 °F	230 °F
Blower shaft power:	5.7 hp	18.7 hp	19.0 hp
Sound pressure level**:	72 dB(A)		
Sound power level**:	87 dB(A)		
Estimated weight:	979 lb		
Dimensions (W x L x H)	39.0 x 45.0 x 51.0 inches		

\* Performance data to DIN ISO 1217- Annex C  
 \*\*Measured to DIN EN ISO 2151, figures ± 3 dB(A), with isolated pipework



Customer: Alabama, NY

Prepared by:

K. Ballew

**Equipment Scope:**

- Inlet silencer w/ filter (grade G4)
- Blower Block w/ Input Shaft Lip Seal
- Oil drains with ball valves
- V-Belt drive w/ automatic belt tensioner
- IP 55 TEFC Inverter rated drive motor (NPE)
- Discharge silencer
- Pressure relief valve
- Vibration isolators
- Sound enclosure with vent fan
- Flexible connectors on inlet and discharge
- Flap style check valve (plate)

**Standard instrumentation:**

- Discharge temperature gauge with switch
- Discharge pressure gauge
- Inlet filter differential pressure gauge

**Supplied**

- yes
- yes
- yes

**Optional accessories:**

- Unloaded Start valve
- Inlet filter differential pressure switch
- Discharge pressure switch
- Discharge pressure sensor (output 4-20mA)
- Enclosure safety temperature switch (thermostat)
- Enclosure heater, 115v (auxiliary heater)
- Outdoor designed sound enclosure

**Supplied**

- no
- no
- no
- no
- no
- no
- no

Comments/ Customer requirements:


**Notes:**

- a. Blower package requires blower controls.
- b. Motors, silencers, instrumentation and supplied accessories shown above are all factory mounted.

# OMEGA 41PLUS

## PRESSURE PERFORMANCE

14,7 PSIA and 68°F



# **Disc Filter Sizing and Equipment Selection**

Project: Alabama DFS  
 Client:  
 Date: 5700132909 9/24/2020

RSM Contact: Wayne Emery  
 Phone: (412) 414-5061  
 Representative Contact:

*CONFIDENTIAL: The information or data contained in this proposal is proprietary to Kruger and should not be copied, reproduced, duplicated, or disclosed to any third party, in whole or part, without the prior written consent of Kruger. This restriction will not apply to any information or data that is available to the public generally.*

Kruger is pleased to propose the Hydrotech Discfilter system for this project. The system design is based on the information listed in the following tables and will be supplied according to Kruger design standards:

Design Parameters		
Influent Source	Effluent from SBR	
Peak Hour Flow	1.36 (944)	MGD (gpm)
Average Day Flow	1.02 (709)	MGD (gpm)
<sup>1</sup> Peak Influent TSS	35	mg/L
<sup>1</sup> Average Influent TSS	20	mg/L
<sup>2</sup> Peak Influent TP	1.00	mg/L
<sup>2</sup> Influent soluble non-reactive P	0.02	mg/L
Monthly Average Effluent TSS	10	mg/L
<sup>2</sup> Monthly Average Effluent TP	0.200	mg/L

<sup>1</sup>Peak TSS includes 15 mg/L solids generated from chemical addition and Average TSS includes 10 mg/L solids generated from chemical addition.

<sup>2</sup>Co-precipitation may be necessary upstream to achieve listed influent P concentrations. The chemical addition must be both flow paced and optimized to limit residual reactive chemical.

Discfilter Design		
Discfilter Model Number	HSF2206-1C	
Total Units (duty/standby)	2 (1/1)	
Total Filter Area Per Unit	362	ft <sup>2</sup>
Submerged Filter Area Per Unit	235	ft <sup>2</sup>
Disc Diameter	2.2	m
Peak Hydraulic Loading Rate	4.02	gpm/ft <sup>2</sup>
Number of Discs Per Unit	6	
Media Pore Size	10	µm
Chassis Material	304 SS	
Cover Material	GRP	
Self-Enclosed Tank Material	304 SS	
SEW Drive Motor	1.5	HP
Backwash Water Pump	7.5	HP
Backwash Pump Rated Flow	41	gpm
Influent Flange	ANSI 12"	
Effluent Flange	ANSI 10"	
Mobile Automated Cleaning System	Included	
Controls System	Allen Bradley	
Unit Control Panel Enclosure Type	NEMA 4X	
Instrumentation - Level Sensors	One (1) lot	






\* Hydraulic loading rate does not include standby unit.

Tertiary Coagulation/Flocculation Design		
Concrete Tankage	By Others	
Coagulation/Flocculation Mixing Details		
Zone	HP	HRT (min)
Rapid Mixing Tank	5.0	0.6
Coagulation Mixing Tank	2.0	5.0
Flocculation Mixing Tank	0.5	5.0
Chemical Feed Equipment		
Polymer Prep + Polymer Feed System	Included	
Coagulant Feed System	Included	

\* Coag/Floc HRT based on 1.36 MGD Peak Flow

A mobile Automated Cleaning System (ACS) is included as part of the equipment supply. The mobile ACS consists of a polyethylene tank, mag drive centrifugal pump, and chemical resistant hose mounted on movable trolley unit. The ACS unit is designed to connect via hose to the chemical spray header within a Discfilter unit, and the ACS connects via 480V receptacle to the control system. The control system will allow for operator initiation of the chemical clean process. Once initiated, the control system provides automatic operation and control of the cleaning process.

1	1/2" THREADED ROD: ASTM F593 W/ B1.1 UNC THDS
2	1/2" FLAT WASHER: ASTM A240 304 SS. PLATE
3	1/2" LOCK WASHER
4	1/2" HEX NUT: ASTM F594 W/ B1.1 UNC THREADS



- NOTES :
1. ALL FLANGE CONNECTIONS: BOLT PATTERN ANSI B16.5. PLATE FLANGE: GALVANIZED, STUB END: AISI 304
  2. DIMENSIONS IN [ ] ARE MM
  3. RECOMMENDED PLATFORM ELEVATION. WORK PLATFORM TO BE SELF SUPPORTING. PLATFORMS MAY NOT BE ATTACHED TO THE FILTER AND LOADS MAY NOT BE TRANSFERRED TO FILTER. PLATFORMS DESIGNED/PROVIDED BY OTHERS.
  4. RECOMMEND 24" MINIMUM MAINTENANCE ACCESS AROUND ENTIRE PERIMETER OF DISCFILTER.
  5. FOLLOW ANCHOR MANUFACTURERS GUIDELINES FOR SPECIFIC INSTALLATION REQUIREMENTS INCLUDING ANCHOR EMBEDMENT AND EDGE DISTANCE. SEISMIC CODE REQUIREMENTS MAY AFFECT ANCHOR DETAIL SHOWN.
  6. ALL ANCHORS AND FASTENERS TO BE STAINLESS STEEL. APPLY ANTI-SEIZE TO ALL CONNECTIONS.


REV	DESCRIPTION	DRAWN	APPR	DATE
B	REVISED NAME	HJH	-	11.15.18
A		CDP	JCC	03.29.18

ALL INFORMATION CONTAINED ON THIS DOCUMENT IS THE PROPERTY OF KRUGER AND/OR ITS AFFILIATES. THE DESIGN CONCEPTS AND INFORMATION CONTAINED HEREIN ARE PROPRIETARY TO KRUGER AND ARE SUBMITTED IN CONFIDENCE. THEY ARE NOT TRANSFERABLE AND MUST BE USED ONLY FOR THE PURPOSE FOR WHICH THE DOCUMENT IS EXPRESSLY SUBMITTED. THEY MUST NOT BE DISCLOSED, REPRODUCED, LOANED OR USED IN ANY OTHER MANNER WITHOUT THE EXPRESS WRITTEN CONSENT OF KRUGER. KRUGER ASSUMES NO RESPONSIBILITY OR LIABILITY FOR THE USE OF THIS DOCUMENT OR THE DESIGN CONCEPTS AND INFORMATION CONTAINED HEREIN FOR ANOTHER PROJECT OR IN A MANNER THAT DOES NOT RELATE TO THE FITNESS OR PURPOSE OF THIS DOCUMENT. IN NO EVENT SHALL THIS DOCUMENT OR THE DESIGN CONCEPTS AND INFORMATION CONTAINED HEREIN BE USED IN ANY MANNER DETRIMENTAL TO THE INTEREST OF KRUGER. ALL PATENT RIGHTS ARE RESERVED ACCEPTANCE OF THE DELIVERY OF THIS DOCUMENT CONSTITUTES AGREEMENT TO THESE TERMS AND CONDITIONS.



<b>DISCFILTER</b> HSF2206-1C, UNIT DRAWING MIXING BYPASS		SCALE 1:40	DRAWING NO 1C.2206.M.12.10	SHEET 1 of 1	REV B
STANDARD PRODUCT					

<b>Date:</b>	5/4/2020
<b>Project City:</b>	Alabama
<b>Project State:</b>	NY
<b>Project Number:</b>	5700132909
<b>Model:</b>	HSF2206/2-1C
<b>Total Flow:</b>	0.20 MGD
<b>Units in Service:</b>	1
<b>Flow per unit:</b>	0.20 MGD




	mm	ft	in	elevation
Inlet Bypass Water Elevation	1,444 mm	4.74 ft	56.9 in	4.74 ft
Bypass Weir	1,425 mm	4.68 ft	56.1 in	4.68 ft
Effluent Water Elevation	988 mm	3.24 ft	38.9 in	3.24 ft
Effluent Weir	970 mm	3.18 ft	38.2 in	3.18 ft
Bottom of Unit	0 mm	0.00 ft	0.0 in	<b>0.00 ft</b>

NOTE: The above diagram is indicative of hydraulic profile only and should not be interpreted as a display of treatment flow path.

<sup>1</sup> - The exact placement of the backwash probe is based on operating observations during installation and startup.

<sup>2</sup> - Please contact Kruger if downstream hydraulic conditions are such that the water level in the effluent collection channel exceeds levels indicated.

<b>Date:</b>	5/4/2020
<b>Project City:</b>	Alabama
<b>Project State:</b>	NY
<b>Project Number:</b>	5700132909
<b>Model:</b>	HSF2206-1C
<b>Total Flow:</b>	1.36 MGD
<b>Units in Service:</b>	1
<b>Flow per unit:</b>	1.36 MGD




	mm	ft	in	elevation
Inlet Bypass Water Elevation	1,495 mm	4.90 ft	58.8 in	4.90 ft
Bypass Weir	1,425 mm	4.68 ft	56.1 in	4.68 ft
Effluent Water Elevation	1,033 mm	3.39 ft	40.7 in	3.39 ft
Effluent Weir	970 mm	3.18 ft	38.2 in	3.18 ft
Bottom of Unit	0 mm	0.00 ft	0.0 in	<b>0.00 ft</b>

NOTE: The above diagram is indicative of hydraulic profile only and should not be interpreted as a display of treatment flow path.


- <sup>1</sup> - The exact placement of the backwash probe is based on operating observations during installation and startup.
- <sup>2</sup> - Please contact Kruger if downstream hydraulic conditions are such that the water level in the effluent collection channel exceeds levels indicated.

# **Coagulation and Flocculation Tank Design**


**Coag/Floc Single Train Layout**  
**Alabama, NY**  
**Total Capacity = 1.36 MGD**  
**Capacity Per Train = 1 x 1.36 MGD**




**Rapid Mix Tank Coagulant Piping**



**Flocculation Tank Polymer Piping**






# **UV Disinfection Sizing and Equipment Selection**

# TROJAN **UV3000PLUS**™

PROPOSAL FOR STAMP - ALABAMA, NY  
QUOTE: 226539  
September 17, 2020



The TrojanUV3000Plus™ is operating in **over 2000** municipal wastewater plants around the world. Disinfecting **over 17 billion** gallons a day, the TrojanUV3000Plus™ has become the reference standard in the industry.



September 17, 2020

CPL  
205 St Paul St Suite 500  
Rochester, NY 14604  
US

Attention: Nick Bayer

In response to your request, we are pleased to provide the following TrojanUV3000Plus™ proposal for the STAMP - ALABAMA project.

The TrojanUV3000Plus™ has been shown in over 2000 installations to provide dependable performance, simplified maintenance, and superior electrical efficiency. As explained in this proposal, the system incorporates innovative features to reduce O&M costs, including variable output electronic ballasts to provide dimming capability and Trojan's revolutionary ActiClean-WW™ system – the industry's only online chemical and mechanical quartz sleeve cleaning system. All Trojan installations are supported by a global network of certified Service Representatives providing local service and support.

Please do not hesitate to call us if you have any questions regarding this proposal. Thank you for the opportunity to quote the TrojanUV3000Plus™ and we look forward to working with you on this project.

With best regards,

*Fiona Crawford*

Fiona Crawford  
3020 Gore Road  
London, Ontario N5V 4T7  
Canada  
(519) 457 – 3400 ext. 2194  
fcrawford@trojanuv.com

**Local Representative:**

Mike Ademovic  
Koester Associates, Inc.  
3101 Seneca Turnpike  
Canastota, NY  
US  
315-967-3800

**DESIGN CRITERIA**

**STAMP - ALABAMA**

Peak Design Flow:	<b>1.36 MGD (current) 2.72 MGD (future)</b>
UV Transmittance:	<b>65 % (minimum)</b>
Total Suspended Solids:	<b>20 mg/l (30 Day Average, grab sample)</b>
Disinfection Limit:	<b>200 Fecal Coliform per 100 ml (30 day Geomean, grab sample)</b>
Design Dose:	<b>30 mJ/cm<sup>2</sup> (bioassay validated)</b>
Validation Factors:	<b>0.98</b> end of lamp life factor (Low-Pressure Amalgam Lamps) <b>0.95</b> fouling factor (ActiClean-WW <sup>™</sup> Chemical / Mechanical Cleaning System)

## DESIGN SUMMARY

**QUOTE: 226539**

Based on the above design criteria, the TrojanUV3000Plus™ proposed consists of:

<b>CHANNEL</b> (Please reference Trojan layout drawings for details.)	
Number of Channels:	<b>1</b>
Approximate Channel Length Required:	<b>30 ft</b>
Channel Width Based on Number of UV Modules:	<b>16 in (flared to 48 in at level controller)</b>
Channel Depth Recommended for UV Module Access:	<b>62 in</b>
<b>UV MODULES</b>	
Total Number of Banks:	<b>2 (1 duty, 1 standby)</b>
Number of Modules per Bank:	<b>4 (2 installed for current conditions, 2 stored modules for future 2.72 MGD)</b>
Number of Lamps per Module:	<b>8</b>
Total Number of UV Lamps:	<b>64 (Including Redundancy)</b>
Maximum Power Draw:	<b>16 kW</b>
<b>UV PANELS</b>	
Power Distribution Center Quantity:	<b>2</b>
System Control Center Quantity:	<b>1 (Touch Smart Controller)</b>
<b>MISCELLANEOUS EQUIPMENT</b>	
Level Controller Quantity:	<b>1</b>
Type of Level Controller:	<b>Serpentine Weir (384 in effective crest length)</b>
Automatic Chemical / Mechanical Cleaning:	<b>Trojan ActiClean-WW™</b>
UV Module Lifting Device:	<b>UV Module Lifting Sling</b>
Standard Spare Parts / Safety Equipment:	<b>Included – 4 lamps, 2 Sleeves, 4 Lampholder Seals, 1 set Wiper Seals, 1 Ballast , 1 Operator's Kit</b>
Other:	<b>2 – 304 SST Channel Reduction Baffles, 8 in. wide</b>
<b>ELECTRICAL REQUIREMENTS</b>	
1.	Each Power Distribution Center requires an electrical supply of one (1) 480/277V, 3-phase, 3-wire + GND, 60 Hz, 8.2 kVA, 14.7 Amps.
2.	The Hydraulic System Center requires an electrical supply of one (1) 480V, 3-phase, 3-wire + GND, 60 Hz, 2.5 kVA.
3.	The System Control Center requires an electrical supply of one (1) 120V, 1-phase, 2-wire + GND, 60 Hz, 1.8 kVA, 15 Amps.
4.	Electrical disconnects required per local code are not included in this proposal.

# **Screw Press Sizing and Equipment Selection**



354 State Route 29, Greenwich, New York 12834  
Phone No 518-695-6851  
E-mail: dan@bdpindustries.com

**Date: Wednesday, July 8, 2020**

**Page: 1 of 6**

**To: Clark Patterson Lee  
205 Saint Paul Street  
Rochester, NY 14604**

**Attn: Nick Bayer  
585-324-0448  
NBayer@CPLteam.com**

**Re: STAMP Project  
Budget Proposal: One (1) BDP DSP 18 Screw Press skid mounted  
BDP Proposal #: 070820-1508**

BDP Industries, Inc. is pleased to offer our quotation for One (1) BDP Screw Press and accessories, skid mounted. The screw press system includes the press, a control panel, polymer system, sludge pump, filtrate recycle system, and wash water pump, all mounted on a stainless steel skid as a complete dewatering system. A discharge conveyor, separate from the skid, is also included in this proposal. Below is a summary description and scope of our proposal.

### **EQUIPMENT DESCRIPTION**

The Screw Press equipment package includes a complete press and appurtenant equipment, skid mounted and described as follows:

1. One (1) 316L stainless steel polymer injection and polymer/sludge mixing system consisting of an injection ring, variable vortex mixer, and reducing fittings.
2. One (1) Screw Press, 18" diameter, with the following design features:
  - a.) 304 stainless steel frame.
  - b.) 304 stainless steel wetted parts.
  - c.) 304 stainless steel hardware.
  - d.) Replaceable wear flights.
  - e.) Automatic, intermittent oscillating screen shower.
  - f.) Filtrate recycle system.
  - g.) Pneumatically adjustable discharge cone.
  - h.) TEFC IP65 severe duty variable speed motors.
  - i.) PVC conduit.
  - j.) NEMA 4X pre-wired junction box.



354 State Route 29, Greenwich, New York 12834  
Phone No 518-695-6851  
E-mail: dan@bdpindustries.com

3. One (1) complete electrical control panel for all Screw Press control functions, drives, and interlocks for the screw press dewatering system. The panel will include an:
  - a) Allen Bradley Compact Logix PLC
  - b) Allen Bradley 12" Panelview plus OIT
  - c) Allen Bradley Powerflex 525 variable frequency drives.
  - d) IEC starter.
  - e) 480/3/60
  - f) UL 508
  - g) NEMA 4X
  - h) 304 stainless steel
4. One (1) Equipment Skid constructed of 304 stainless steel with integral filtrate collection sump and grating for walk-ways. All equipment in this proposal except for the discharge conveyor will be mounted and affixed to the equipment skid and will be pre-wired and pre-plumbed at the BDP factory.
5. One (1) Seepex, Netzsch or MXQ Progressive Cavity sludge feed pump with 5 HP TEFC drive motor capable of pumping 75 GPM at 300 RPM and 50 psi of head pressure
6. One (1) UGSI Automatic emulsion polymer blending unit with 5 GPH progressive cavity neat polymer pump, motorized mixing chamber and 1,200 GPH dilution water capability.
7. One (1) 3" Diameter Siemens Magnetic Flow Meter.
8. One (1) Washwater Booster Pump.
9. One (1) Filtrate Recycle System with Moyno 34401 pump and pressure transducer for automatic level control.
10. One (1) Ingersoll Rand Air Compressor and Air Drier.
11. One (1) 3 HP 304 stainless steel inclined u-trough screw conveyor, 18 ft in length, capable of 110 CFH. Conveyor supports included.
12. One-year warranty.
13. Six (6) days of on-site start-up spread over two trips for start up, mechanical checkout and operator training.
14. Freight to the jobsite.



354 State Route 29, Greenwich, New York 12834  
Phone No 518-695-6851  
E-mail: dan@bdpindustries.com

15. Optional for Future Addition: One (1) 36" diameter Rotary Drum Thickener with a variable speed drive motor.
- a) 304 stainless steel frame
  - b) 304 stainless steel wetted parts.
  - c) 304 stainless steel hardware.
  - d) TEFC IP65 severe duty variable speed motors.
  - e) PVVC conduit.
  - f) NEMA 4X pre-wired Junction box.

The Screw Press will come completely factory-assembled, tested and will be shipped in one piece. The polymer injection devices, polymer make down unit, electrical control panel and all ancillary equipment will be skid-mounted, except for the screw conveyor. This quotation is for furnishing equipment only and does not include any other installation labor or field services other than checkout and start up services as listed above. The price does not include any applicable taxes or installation. BDP is not responsible for obtaining installation or operating permits, if required, or any additional permit fees.



#### **SHIPMENT**

Approximate shipping weight of the unit is 13,500 pounds. Estimated shipping time is 20 to 26 weeks after receipt of purchase order.

#### **FIELD SERVICE**

Startup services shall include six (6) days over two trips of on-site start-up, mechanical checkout and operator training.





CONNECTION LEGEND:

- ◇ 5" 150# FLANGED FEED INLET
- ◇ 1-1/2" NPT WASHWATER INLET
- ◇ 6" NPT MAIN COLLECTION PAN OUTLET

PLUMBING BEYOND THESE POINTS NOT SUPPORTED BY BDP

QTY.	DESCRIPTION	MAT.	ITEM	REMARKS
		<b>BDP INDUSTRIES, INC.</b> GREENWICH, N.Y. 12834		
CUSTOMER: STAMP, NY	MACHINE: DSP 18x12	DWG TITLE GENERAL ARRANGEMENT		
BDP JOB NO. PROPOSAL	DWN BY: SKD	DATE: 9/18/20	SKIDDED DSP 18x12 SCREW PRESS	
APP'D BY:	SCALE:	SHT. OF 1 1	DWG NO. 1-800-227	REV. 1

REV.	DESCRIPTION	BY	DATE

# **Sanitary Sewer Pump Selection**

## Data sheet



Customer item no.: Temporary PS  
Communication dated: 10/06/2020  
Doc. no.: Rochester, NY  
Quantity: 4

Number: ES 8000472153  
Item no.: 100  
Date: 10/06/2020  
Page: 1 / 21

### KRTE 100-317/374XEG-S

Version no.: 1

#### Operating data

Requested flow rate	584.00 US GPM	Actual flow rate	601.38 US GPM
Requested developed head	130.00 ft	Actual developed head	137.85 ft
Pumped medium	Wastewater, municipal biologically treated Not containing chemical and mechanical substances which affect the materials	Efficiency	67.4 %
Max. ambient air temperature	68.0 °F	Power absorbed	31.02 HP
Min. ambient air temperature	68.0 °F	Pump speed of rotation	1776 rpm
Fluid temperature	104.0 °F	Max. power on curve	42.59 HP
		Shutoff head	184.50 ft
		Design	Single system 1 x 100 %
Fluid density	62.303144 lb/ft <sup>3</sup>	Performance test	Yes
Fluid viscosity	0.0010 in <sup>2</sup> /s		
Ex-Request acc.to Atex	II T3		

#### Design

Design	Close-coupled submersible	Impeller type	Single vane, radial flow (E)
Orientation	Vertical	Wear ring	Casing wear ring
Suction flange pump drilled according to(DN1)	unmachined	Impeller diameter	12.40 in
Discharge flange pump drilled according to(DN2)	EN 1092-2 / DN 100 / PN 10	Free passage size	2.99 in
Shaft seal	2 mech. seals in tandem arrangement with oil reservoir	Direction of rotation from drive	Clockwise
Manufacturer	KSB	Ex protection	Explosion protection to NEC Class1, Div 1, Gr.C, D T3
Type	MG	Color	Ultramarine blue (RAL 5002) KSB-blue
Material code	SIC/SIC/NBR		

#### Driver, accessories

Driver type	Electric motor	Motor service factor	1.15
Model (make)	KSB	Temperature sensor	Bimetal switch / PTC
Motor const. type	KSB Sub. motor	Motor winding	460 V
NEMA code letter	G	Number of poles	4
Frequency	60 Hz	Starting mode	Direct-on-line starting
Rated voltage	460 V	Connection mode	Delta
Rated power P2	49.99 HP	Motor cooling method	Surface cooling
Available reserve	61.14 %	Motor version	X
Rated current	60.3 A	Cable design	Rubber hose
Starting current ratio	6.4	Cable entry	Sealed along entire length
Insulation class	H according IEC 34-1	Power cable	AWG 7-7+15-5
Type of protection	XP/II/1/CD	Number of power cables	1
Motor enclosure	IP68	Moisture sensor	With
Cos phi at 4/4 load	0.84	Cable length	32.81 ft
Motor efficiency at 4/4 load	92.4 %		

#### Materials G

Pump casing (101)	Cast iron A 48 Class 35 B	O-Ring (412)	Nitrile rubber NBR
Discharge cover (163)	Cast iron A 48 Class 35 B	Casing wear ring (502.1)	Cast iron A 48 Class 35 B
Shaft (210)	Chrome steel ASTM A276 Type 420 T	Motor housing (811)	Cast iron A 48 Class 35 B
Impeller (230)	Cast iron A 48 Class 35 B	Motor cable (824)	Chloroprene rubber
Bearing bracket (330)	Cast iron A 48 Class 35 B	Screw (900)	Stainless steel A 193 B8M

## Data sheet



Customer item no.: Temporary PS  
Communication dated: 10/06/2020  
Doc. no.: Rochester, NY  
Quantity: 4

Number: ES 8000472153  
Item no.: 100  
Date: 10/06/2020  
Page: 2 / 21

**KRTE 100-317/374XEG-S**

Version no.: 1

### Nameplates

Nameplates language	International	Duplicate nameplate	With
---------------------	---------------	---------------------	------

### Certifications

<b>Hydraulic performance test</b>		Test participation	Non-witnessed
Acceptance standard	ISO 9906 & ANSI HI Class 2B	Quantity, non-witnessed	4
Quantity meas. points Q-H	5	Quantity, witnessed	0
Certificate	Inspection cert. 3.1 to EN 10204		

### Installation parts

Installation type	stationary 2 guide rail	Mounting type	Composite anchor bolts
Scope of supply	Pump with installation parts For guide rail arrangements, the guide rails are not included in KSB's scope of supply.	Foundation rail	Without
Installation depth	14.76 ft	<b>Claw</b>	
Material concept	G	Design	Straight
		Size	DN 100
		<b>Lifting chain / -rope</b>	
		Lifting Bail	Without With

### Duckfoot bend

Size	DN 100
Flange design	ASME
Duckfoot bend size (DN2 / DN3)	DN 100 Drilled according to ASME
Material	Cast iron A 48 Class 35 B

# Performance curve




Customer item no.: Temporary PS  
 Communication dated: 10/06/2020  
 Doc. no.: Rochester, NY  
 Quantity: 4

Number: ES 8000472153  
 Item no.: 100  
 Date: 10/06/2020  
 Page: 3 / 21

## KRTE 100-317/374XEG-S

Version no.: 1



### Curve data

Speed of rotation	1776 rpm	Efficiency	67.4 %
Fluid density	62.303144 lb/ft <sup>3</sup>	Power absorbed	31.02 HP
Viscosity	0.0010 in <sup>2</sup> /s	NPSH req. 3%	9.97 ft
Flow rate	601.38 US GPM	Curve number	K43480
Requested flow rate	584.00 US GPM	Effective impeller diameter	12.40 in
Total developed head	137.85 ft	Acceptance standard	ISO 9906 & ANSI HI Class 2B
Requested developed head	130.00 ft		

# Speed curve




Customer item no.: Temporary PS  
 Communication dated: 10/06/2020  
 Doc. no.: Rochester, NY  
 Quantity: 4

Number: ES 8000472153  
 Item no.: 100  
 Date: 10/06/2020  
 Page: 4 / 21

**KRTE 100-317/374XEG-S**

Version no.: 1



### Curve data

Fluid density	62.303144 lb/ft <sup>3</sup>	Total developed head	137.85 ft
Viscosity	0.0010 in <sup>2</sup> /s	Requested developed head	130.00 ft
Flow rate	601.38 US GPM	Effective impeller diameter	12.40 in
Requested flow rate	584.00 US GPM		

# Motor data sheet



Customer item no.: Temporary PS  
 Communication dated: 10/06/2020  
 Doc. no.: Rochester, NY  
 Quantity: 4

Number: ES 8000472153  
 Item no.: 100  
 Date: 10/06/2020  
 Page: 5 / 21

## KRTE 100-317/374XEG-S

Version no.: 1


### Motor data

Motor manufacturer	KSB	Rated speed	1770 rpm
Motor size	37E	Starting current ratio	6.4
Motor construction type	KSB Sub. motor	Starting mode	Direct-on-line starting
Motor material	Grey cast iron EN-GJL-250	Power cable	AWG 7-7+15-5
Efficiency class	not classified	Number of power cables	1
Rated voltage	460 V	Power cable Ø min.	0.96 in
Frequency	60 Hz	Power cable Ø max.	1.08 in
Motor power	49.99 HP	Cable standard	NEC
Rated current	60.3 A	Switching frequency	10.00 1/h

### Curve data

The no-load point is not a guarantee point within the meaning of IEC 60034

Load	0.0 %	25.0 %	50.0 %	75.0 %	100.0 %
P2	0.00 HP	12.50 HP	25.00 HP	37.49 HP	49.99 HP
n	1800 rpm	1790 rpm	1781 rpm	1771 rpm	1770 rpm
P1	1.61 HP	14.34 HP	27.36 HP	40.67 HP	54.11 HP
I	22.6 A	26.3 A	35.1 A	47.0 A	60.3 A
Eta	0.0 %	87.2 %	91.4 %	92.2 %	92.4 %
cos phi	0.07	0.51	0.73	0.81	0.84



# Installation plan




Customer item no.: Temporary PS  
 Communication dated: 10/06/2020  
 Doc. no.: Rochester, NY  
 Quantity: 4

Number: ES 8000472153  
 Item no.: 100  
 Date: 10/06/2020  
 Page: 6 / 21

**KRTE 100-317/374XEG-S**

Version no.: 1



*Drawing is not to scale*

*Dimensions in in*

# Installation plan



Customer item no.: Temporary PS  
Communication dated: 10/06/2020  
Doc. no.: Rochester, NY  
Quantity: 4

Number: ES 8000472153  
Item no.: 100  
Date: 10/06/2020  
Page: 7 / 21

## KRTE 100-317/374XEG-S

Version no.: 1

### Motor

Motor manufacturer	KSB
Motor size	37E
Motor power	49.99 HP
Number of poles	4
Speed of rotation	1770 rpm
Motor enclosure	IP68

### Connections

Suction flange pump drilled according to(DN1)	unmachined
Duckfoot bend size (DN2 / DN3)	DN 100 Drilled according to ASME

### Weight net

Pump, Motor, Cable	952 lbm
Claw / Foot	32 lbm
Total	984 lbm

### Connect pipes without stress or strain!

Dimensional tolerances for shaft axis height: DIN 747  
Dimensions without tolerances, middle tolerances to:  
Connection dimensions for pumps:  
Dimensions without tolerances - welded parts:  
Dimensions without tolerances - gray cast iron parts:  
Dimensions without tolerances - stainless steel parts:

ISO 2768-m  
EN735  
ISO 13920-B  
ISO 8062-CT11  
ISO 8062-CT12

**For auxiliary connections see separate drawing.**

## Data sheet



Customer item no.: Permanent PS  
Communication dated: 10/06/2020  
Doc. no.: Rochester, NY  
Quantity: 4

Number: ES 8000472153  
Item no.: 300  
Date: 10/06/2020  
Page: 15 / 21

### KRTK 150-503/1554XNG-S

Version no.: 1

#### Operating data

Requested flow rate	1533.00 US GPM	Actual flow rate	1533.17 US GPM
Requested developed head	354.00 ft	Actual developed head	354.08 ft
Pumped medium	Wastewater, municipal biologically treated Not containing chemical and mechanical substances which affect the materials	Efficiency	71.9 %
Max. ambient air temperature	68.0 °F	Power absorbed	190.08 HP
Min. ambient air temperature	68.0 °F	Pump speed of rotation	1781 rpm
Fluid temperature	104.0 °F	Max. power on curve	269.36 HP
		Shutoff head	434.30 ft
		Design	Single system 1 x 100 %
Fluid density	62.303144 lb/ft <sup>3</sup>	Performance test	Yes
Fluid viscosity	0.0010 in <sup>2</sup> /s		
Ex-Request acc.to Atex	II T3		

#### Design

Design	Close-coupled submersible	Impeller type	Multivane radial flow impeller (K-max)
Orientation	Vertical	Wear ring	Casing wear ring
Suction flange pump drilled according to(DN1)	unmachined	Impeller diameter	18.78 in
Discharge flange pump drilled according to(DN2)	EN 1092-2 / DN 150 / PN 10	Free passage size	2.99 in
Shaft seal	2 mech. seals in tandem arrangement with oil reservoir	Direction of rotation from drive	Clockwise
Manufacturer	KSB	Ex protection	Explosion protection to NEC Class1, Div 1, Gr.C, D T3
Type	MG	Temperature sensor PT100 inboard	With
Material code	SIC/SIC/NBR	Color	Ultramarine blue (RAL 5002) KSB-blue

#### Driver, accessories

Driver type	Electric motor	Temperature sensor	Bimetal switch / PTC
Model (make)	KSB	Motor winding	460 V
Motor const. type	KSB Sub. motor	Number of poles	4
NEMA code letter	F	Starting mode	Direct-on-line starting
Frequency	60 Hz	Connection mode	Delta
Rated voltage	460 V	Motor cooling method	Surface cooling
Rated power P2	208.01 HP	Motor version	X
Available reserve	9.43 %	Cable design	Rubber hose
Rated current	232.0 A	Cable entry	Sealed along entire length
Starting current ratio	6.1	Power cable	AWG 1/0-4
Insulation class	H according IEC 34-1	Number of power cables	2
Type of protection	XP/II/1/CD	Control cable	AWG 15-10
Motor enclosure	IP68	Number of control cables	1
Cos phi at 4/4 load	0.90	Moisture sensor	With
Motor efficiency at 4/4 load	93.3 %	Cable length	32.81 ft
Motor service factor	1.15		

## Data sheet



Customer item no.: Permanent PS  
Communication dated: 10/06/2020  
Doc. no.: Rochester, NY  
Quantity: 4

Number: ES 8000472153  
Item no.: 300  
Date: 10/06/2020  
Page: 16 / 21

### KRTK 150-503/1554XNG-S

Version no.: 1

#### Materials G

Pump casing (101)	Cast iron A 48 Class 35 B	Casing wear ring (502.1)	Cast iron A 48 Class 35 B
Discharge cover (163)	Cast iron A 48 Class 35 B	Shaft protecting sleeve (524)	Chrome steel A 276 Type 420
Shaft (210)	Chrome steel ASTM A276 Type 420 T	Motor housing (811)	Cast iron A 48 Class 35 B
Impeller (230)	Cast iron A 48 Class 35 B	Motor cable (824)	Chloroprene rubber
Bearing bracket (330)	Cast iron A 48 Class 35 B	Screw (900)	Stainless steel A 193 B8M
O-Ring (412)	Nitrile rubber NBR		

#### Nameplates

Nameplates language	International	Duplicate nameplate	With
---------------------	---------------	---------------------	------

#### Certifications

##### Hydraulic performance test

Acceptance standard	ISO 9906 & ANSI HI Class 2B	Test participation	Non-witnessed
Quantity meas. points Q-H	5	Quantity, non-witnessed	4
Certificate	Inspection cert. 3.1 to EN 10204	Quantity, witnessed	0

#### Installation parts

Installation type	stationary 2 guide rail	Mounting type	Composite anchor bolts
Scope of supply	Pump with installation parts For guide rail arrangements, the guide rails are not included in KSB's scope of supply.	Foundation rail	Without
Installation depth	14.76 ft	<b>Claw</b>	
Material concept	G	Design	Straight
		Size	DN 150
		<b>Lifting chain / -rope</b>	
		Lifting Bail	Without With

#### Duckfoot bend

Size	DN 150
Flange design	ASME
Duckfoot bend size (DN2 / DN3)	DN 150 Drilled according to ASME
Material	Cast iron A 48 Class 35 B

# Performance curve




Customer item no.:Permanent PS  
 Communication dated: 10/06/2020  
 Doc. no.: Rochester, NY  
 Quantity: 4

Number: ES 8000472153  
 Item no.:300  
 Date: 10/06/2020  
 Page: 17 / 21

## KRTK 150-503/1554XNG-S

Version no.: 1



### Curve data

Speed of rotation	1781 rpm	Efficiency	71.9 %
Fluid density	62.303144 lb/ft <sup>3</sup>	Power absorbed	190.08 HP
Viscosity	0.0010 in <sup>2</sup> /s	NPSH req. 3%	11.32 ft
Flow rate	1533.17 US GPM	Curve number	K43629/0
Requested flow rate	1533.00 US GPM	Effective impeller diameter	18.78 in
Total developed head	354.08 ft	Acceptance standard	ISO 9906 & ANSI HI Class 2B
Requested developed head	354.00 ft		

# Speed curve




Customer item no.:Permanent PS  
 Communication dated: 10/06/2020  
 Doc. no.: Rochester, NY  
 Quantity: 4

Number: ES 8000472153  
 Item no.:300  
 Date: 10/06/2020  
 Page: 18 / 21

## KRTK 150-503/1554XNG-S

Version no.: 1



### Curve data

Fluid density	62.303144 lb/ft <sup>3</sup>	Total developed head	354.00 ft
Viscosity	0.0010 in <sup>2</sup> /s	Requested developed head	354.00 ft
Flow rate	1533.00 US GPM	Effective impeller diameter	18.78 in
Requested flow rate	1533.00 US GPM		

# Motor data sheet



Customer item no.: Permanent PS  
 Communication dated: 10/06/2020  
 Doc. no.: Rochester, NY  
 Quantity: 4

Number: ES 8000472153  
 Item no.: 300  
 Date: 10/06/2020  
 Page: 19 / 21

## KRTK 150-503/1554XNG-S

Version no.: 1



### Motor data

Motor manufacturer	KSB	Starting mode	Direct-on-line starting
Motor size	155N	Power cable	AWG 1/0-4
Motor construction type	KSB Sub. motor	Number of power cables	2
Motor material	Grey cast iron EN-GJL-250	Power cable Ø min.	1.37 in
Efficiency class	not classified	Power cable Ø max.	1.45 in
Rated voltage	460 V	Control cable	AWG 15-10
Frequency	60 Hz	Number of control cables	1
Motor power	208.01 HP	Ctrl. cable diameter, min.	0.63 in
Rated current	232.0 A	Ctrl. cable diameter, max.	0.67 in
Rated speed	1779 rpm	Cable standard	NEC
Starting current ratio	6.1	Switching frequency	10.00 1/h

### Curve data

The no-load point is not a guarantee point within the meaning of IEC 60034

Load	0.0 %	25.0 %	50.0 %	75.0 %	100.0 %
P2	0.00 HP	52.00 HP	104.00 HP	156.00 HP	208.01 HP
n	1800 rpm	1795 rpm	1789 rpm	1784 rpm	1779 rpm
P1	7.55 HP	59.14 HP	112.24 HP	166.82 HP	223.01 HP
I	51.5 A	81.0 A	121.0 A	172.0 A	232.0 A
Eta	0.0 %	87.9 %	92.7 %	93.5 %	93.3 %
cos phi	0.14	0.68	0.87	0.91	0.90



# Installation plan




Customer item no.: Permanent PS  
 Communication dated: 10/06/2020  
 Doc. no.: Rochester, NY  
 Quantity: 4

Number: ES 8000472153  
 Item no.: 300  
 Date: 10/06/2020  
 Page: 20 / 21

**KRTK 150-503/1554XNG-S**

Version no.: 1



Drawing is not to scale

Dimensions in in

## Installation plan



Customer item no.:Permanent PS  
Communication dated: 10/06/2020  
Doc. no.: Rochester, NY  
Quantity: 4

Number: ES 8000472153  
Item no.:300  
Date: 10/06/2020  
Page: 21 / 21

**KRTK 150-503/1554XNG-S**

Version no.: 1

### Motor

Motor manufacturer	KSB
Motor size	155N
Motor power	208.01 HP
Number of poles	4
Speed of rotation	1779 rpm
Motor enclosure	IP68

### Connections

Suction flange pump drilled according to(DN1)	unmachined
Duckfoot bend size (DN2 / DN3)	DN 150 Drilled according to ASME

### Weight net

Pump, Motor, Cable	3532 lbm
Claw / Foot	49 lbm
Total	3580 lbm

### Connect pipes without stress or strain!

Dimensional tolerances for shaft axis height: DIN 747  
Dimensions without tolerances, middle tolerances to:  
Connection dimensions for pumps:  
Dimensions without tolerances - welded parts:  
Dimensions without tolerances - gray cast iron parts:  
Dimensions without tolerances - stainless steel parts:

ISO 2768-m  
EN735  
ISO 13920-B  
ISO 8062-CT11  
ISO 8062-CT12

**For auxiliary connections see separate drawing.**